

कार्यालय सहायक अभियंता,
लोक स्वास्थ्य यांत्रिकी उपखण्ड,
रायपुर (छ.ग.)

क्रमांक ...170.....जि.प्र.शा./लो.स्वा.या./उपखण्ड रायपुर

दिनांक 01/06/2026

प्रति,

Principal
Krishna Public School
Tendua, Raipur (C.G.)

विषय :- जल नमूनों के परीक्षण रिपोर्ट प्रेषित करने बाबत।

संदर्भ :- आपका पत्र क्रमांक. - दिनांक 29.05.2026

उपरोक्त विषयान्तर्गत लेख है कि संदर्भित पत्र के माध्यम से प्राप्त जल नमूने का, जिला जल परीक्षण प्रयोगशाला लोक स्वास्थ्य यांत्रिकी विभाग रायपुर में परीक्षण कर रिपोर्ट आपकी ओर प्रेषित है।

संलग्न :- रिपोर्ट नंबर - 355 एवं बिल नंबर - 129 की एक प्रति।

सहायक अभियंता

लोक स्वास्थ्य यांत्रिकी उपखण्ड

रायपुर (छ.ग.)

Principal
Krishna Public School
Tendua, Raipur (C.G.)

Manager
Krishna public School
Tendua, Raipur (C.G.)

जिला जल परीक्षण प्रयोगशाला
लोकस्वास्थ्य यांत्रिकी विभाग रिंगरोड 1, रावणभाटा, रायपुर (छ.ग.)
DISTRICT WATER TESTING LABOARATORY, PHED.
RING ROAD NO.1 RAWANBHANTA RAIPUR (C.G.)
email:- dwtiraipur@gmail.com

TEST REPORT

Report No. DL/PHED/RPR : 355	Discipline:- Chemical Testing	Type of Sample : Drinking Water		
Senders Name & Address:- Principal Krishna Public School Tendua, Raipur (C.G.)	Senders Letter No./Date	-/ 29.05.2026	Sampled by & Date	Customer 29.05.2026
	DL Receipt no.	355	DL Receipt Date	29.05.2026
	Date of Analysis Started	29.05.2026	Date of Analysis Completed	31.05.2026
	Location	Permanent Facility		

SAMPLE DETAILS

S.N.	Sample I.D.	District / Block	City / Village	Habita.	Location/Source ID./GPS Identification
1.	355/1958/05/2026	Raipur	Raipur	-	Water Sample Of, Krishna Public School
-	-	-	-	-	-
-	-	-	-	-	-
-	-	-	-	-	-

DETAILS OF PARAMETERS THEIR TEST METHOD UNITS AND SPECIFICATION AS PER IS/APHA


S.N.	Parameters	Test method IS 3025/APHA 24 th ed.	Unit	As per IS-10500-2012 drinking water		Result			
				Acceptable Limit	Permissible Limit	S.No. 1	-	-	-
1	Chloride	IS 3025 (Part- 32) : 2025	mg/l.	250	1000	33.95	-	-	-
2	Alkalinity as CaCO ₃	IS 3025 (Part-23) : 2023	mg/l.	200	600	227.29	-	-	-
3	Total Hardness as CaCO ₃	IS 3025 (Part-21) : 2023	mg/l.	200	600	189.88	-	-	-
4	Calcium	IS 3025 (Part-40) : 2024	mg/l.	75	200	49.48	-	-	-
5	Magnesium	APHA 24 th ed.3500 Mg-B	mg/l.	30	100	16.14	-	-	-
6	Fluoride	APHA 24 th ed.4500-F- C	mg/l.	1.0	1.5	0.263	-	-	-
7	TDS	APHA 24 th ed.2540-solid C	mg/l.	500	2000	358	-	-	-
8	Spe.Conductivity @25°C	IS 3025 (Part- 14) : 2023	µmho/cm	-	-	480.52	-	-	-
9	pH @ 25°C	IS 3025(Part-11) : 2022	PH scale	6.5-8.5	6.5-8.5	7.72	-	-	-
10	Turbidity	IS 3025(Part-10) : 2023	NTU	1	5	0.99	-	-	-
11	Taste	IS 3025 (Part 8) : 2023	Part- 8	Agreeable	Agreeable	-	-	-	-
12	Colour	APHA 24 th ed.2120-B	Hazen	05	15	5	-	-	-
13	Odour	IS 3025 (Part -5) : 2018	-	Agreeable	Agreeable	Agreeable	-	-	-

Remark:-

1. The report should not be produced partly or full without approval signatory authority of legal purpose.
2. The results refer only to tested samples and parameters.
3. Samples will be stored for a period of 10 days from date of issue of report.
4. This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
5. Results apply to the sample as received.7. Sampling not done by Lab staff.

Tested by


(Mani Shankar Roy)
Chemist


Principal
Krishna Public School
Tendua, Raipur (C.G.)


Manager
Krishna public School
Tendua, Raipur (C.G.)

Report Reviewed & Approved by


(Umesh Sahu)
Authorized Signatory

जिला जल परीक्षण प्रयोगशाला
लोकस्वास्थ्य यांत्रिकी विभाग रिंगरोड 1, रावणभाटा, रायपुर (छ.ग.)
DISTRICT WATER TESTING LABOARATORY, PHED.
RING ROAD NO.1 RAWANBHANTA RAIPUR (C.G.)
email:- dwtlraipur@gmail.com

TEST REPORT

Report No. DL/PHED/RPR : 355	Discipline:- Chemical Testing	Type of sample : Drinking Water		
Senders name & Address:- Principal Krishna Public School Tendua, Raipur (C.G.)	Senders letter no./Date	-/ 29.05.2026	Sampled by & Date	Customer 29.05.2026
	DL receipt no.	355	DL Receipt Date	29.05.2026
	Date of analysis started	29.05.2026	Date of Analysis Completed	31.05.2026
	Location	Permanent Facility		

SAMPLE DETAILS

S.N.	Sample I.D.	District / Block	City / Village	Habita.	Location/Source ID./GPS Identification
1.	355/1958/05/2026	Raipur	Raipur	-	Water Sample Of, Krishna Public School
-	-	-	-	-	-
-	-	-	-	-	-
-	-	-	-	-	-

DETAILS OF PARAMETERS THEIR TEST METHOD UNITS AND SPECIFICATION AS PER IS/APHA

S.N.	Parameters	Test method IS 3025/APHA 24 th ed.	Unit	As per IS-10500-2012 drinking water		Result Of S.No.			
				Acceptable Limit	Permissible Limit	S.No. 1	-	-	-
14	Iron	APHA 24 th ed. 3500-Fe-B	mg/l.	1.0	No relaxation	0.049	-	-	-
15	Nitrates	APHA 24 th ed. 4500-NO ₃ -B	mg/l.	45	No relaxation	3.059	-	-	-
16	Sulphate	IS 3025 (Part -24)	mg/l.	200	400	5.126	-	-	-
17	Manganese	APHA 24 th ed. 3500Mn-B.	Mg/l.	0.1	0.3	0.01	-	-	-
18	Residual Chlorine	-	mg/l.	0.2	1.0	0.00	-	-	-

BACTERIOLOGICAL - TEST REPORT

DETAILS OF PARAMETERS THEIR TEST METHOD UNITS AND SPECIFICATION AS PER IS/APHA

19	Total Coliform	IS / APHA	Cfu/100mL.	Nil	Nil	-	-	-	-
20	E.Coli	IS / APHA	Cfu/100mL.	Nil	Nil	Nil	-	-	-

Remark:-

1. The report should not be produced partly or full without approval signatory authority of legal purpose.
2. The results refer only to tested samples and parameters.
3. Samples will be stored for a period of 10 days from date of issue of report.
4. This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
5. Results apply to the sample as received. 7. Sampling not done by Lab staff.

Tested by

(Mani Shankar Roy)
Chemist

Principal
Krishna Public School
Tendua: Raipur (C.G.)

Manager
Krishna public School
Tendua, Raipur (C.G.)

Report Reviewed & Approved by

(Umesh Sahu)
Authorized Signatory

Issue no. 355 / Date- 01.06.2026

Page no. 01/01

End of Report

जिला जल परीक्षण प्रयोगशाला
लोकस्वास्थ्य यांत्रिकी विभाग रिंगरोड 1, रावणभाटा, रायपुर (छ.ग.)
DISTRICT WATER TESTING LABOARATORY, PHED.
RING ROAD NO.1 RAWANBHANTA RAIPUR (C.G.)
email:- dwtlraipur@gmail.com

INVOICE

(Water Sample Analysis Charge)

Date -01.06.2026

Invoice no. 129

To

Principal
Krishna Public School
Tendua, Raipur (C.G.)
(Letter no. - दिनांक 29.05.2026)

DESCRIPTION

Sr. no.	parameters	Fee in Rs. Per sample	Required parameter tick (✓)	Total fee in Rs. according to no. of sample = 01
1	Colour	1.00	✓	1.00
2	Odour	1.00	✓	1.00
3	Turbidity in NTU	5.00	✓	5.00
4	PH	1.00	✓	1.00
5	Total Alkalinity as CaCO ₃ in mg/l.	20.00	✓	20.00
6	TDS in mg/l.	1.00	✓	1.00
7	Spe. Conductivity @ 25°C	1.00	✓	1.00
8	Chloride in Mg/l.	50.00	✓	50.00
9	Nitrate in mg/l.	50.00	✓	50.00
10	Calcium as Ca++ in mg/l.	20.00	✓	20.00
11	Magnesium as Mg ++ in mg/l	20.00	✓	20.00
12	Manganese	50.00	✓	50.00
13	Total Hardness as CaCO ₃ in mg/l.	20.00	✓	20.00
14	Iron in mg/l.	50.00	✓	50.00
15	Sulphate mg/l.	50.00	✓	50.00
16	Fluoride in mg/l.	50.00	✓	50.00
17	Residual Chlorine in mg/l.	1.00	✓	1.00
18	E.Coli	100.00	✓	100.00
			Grand Total	491.00

[Invoice Amount In words ₹. Four Hundred Ninety One Rupees only]

Chemist
District Water Testing Laboratory
PHED Raipur (C.G.)

Principal
Krishna Public School
Tendua, Raipur (C.G.)

Assistant Engineer
PHE Sub Division
Raipur (C.G.)

■ " सहायक अभियंता, लोक स्वास्थ्य यांत्रिकी उपखण्ड रायपुर, " के नाम से चेक / डी.डी. का भूगतान करें।

कार्यालय मुख्य चिकित्सा एवं स्वास्थ्य अधिकारी,

जिला – रायपुर (छ.ग.)

(Email-cmho_raipur@yahoo.co.in Ph-0771-2535304)

क्रमांक / सीएमएचओ / सत्रह / 2025 / 24021

रायपुर दिनांक 25/07/2025

REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by DR. S. K. Vohra DHO (Name of Officers with designation) from CHIEF MEDICAL AND HEALTH OFFICER RAIPUR (C.G.) (Name of Department/Office) inspected the KRISHNA PUBLIC SCHOOL RAIPUR DISTTI. RAIPUR (C.G.) (Name & Address of the School) on 21-07-2025 and found that KRISHNA PUBLIC SCHOOL NADANVAN ROAD, NEAR BANGLAMUKHI MANDIR (VILG. TENDUA) RAIPUR DISTTI. RAIPUR (C.G.) (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid Certificate is for a period of ONE YEAR FROM DATE OF ISSUE.

The Chief Medical & Health Officer
C.M. District - Raipur (C.G.)

TO,

PRINCIPAL
KRISHNA PUBLIC SCHOOL
TENDUA, RAIPUR
DISTTI. RAIPUR (C.G.)


Principal
Krishna Public School
Tendua, Raipur (C.G.)


Manager
Krishna public School
Tendua, Raipur (C.G.)