

MEGA MOTOR COMPANY PVT. LTD. INSTALLATION OF MMC / BYD EV ASSEMBLY PLANT AT GHARO ELECTRICAL BOQ FOR LV DISTRIBUTION PANELS (Option 02-Ravi Switchgear Make Form 4b Local Solution)											
SR#	DESCRIPTION	UNIT		QTY	SUPPLY UNIT RATE (PKR)		SUPPLY TOTAL RATE (PKR)	INSTALLATION ON UNIT RATE (PKR)		TOTAL AMOUNT (PKR) G=D+F	REMARKS / REFERENCE
		A	B		C	D=BXC		E	F=BXE		
1	LOW VOLTAGE POWER DISTRIBUTION PANELS										
	H2 LOW VOLTAGE POWER DISTRIBUTION PANEL TYPE TESTED, FORM 4B TYPE 6, 12 SWG, FULL RATED 1P+N-E BUSBAR, IEC-60847-2 COMPLIED BREAKER WITH COMPLETE GADGET AND METERING AS PER REFERRED SCHEMATICS AND SPECIFICATIONS AND SHALL BE COMPLIANCE WITH IEC 61439, BS 61439, IEC 60529 AND RELEVANT IEC & GB STANDARDS INCLUDING FABRICATION, FIXING / BOLTING OF GALVANIZED STEEL BASE FRAMES FOR PANEL MOUNTING WITH ALL ASSOCIATED MOUNTING AND INSTALLATION ACCESSORIES INCLUDING DELIVERY AT SITE WITH LOADING AND UNLOADING THROUGH CERTIFIED CRANE WITH OPERATOR AND RIGGERS. COMPLETE IN ALL RESPECTS.										
1.1	CONTRACTOR SHOULD SUBMIT THE SHOP DRAWINGS FOR APPROVAL BEFORE COMMENCEMENT OF WORK. FURTHERMORE, SCOPE ALSO INCLUDES ALL EARTHING CONNECTIONS OF THE PANELS / AUXILIARIES COMPLETE WITH EQUIPOTENTIAL BONDING OF THE SYSTEM COMPLETE IN ALL RESPECTS.										
1.1.1	1T1-1AN1										
1.1.2	1T1-1AN2										
1.1.3	1T1-1AN3	1	NO.		13,341,564		13,341,564	395,000		13,736,564	BODY WELDING SHOP (1T1)
1.1.4	1T1-1AN4										
1.1.5	1T3-3AN1										
1.1.6	1T3-3AN2										
1.1.7	1T3-3AN3										
1.1.8	1T3-3AN4	1	NO.		20,289,026		20,289,026	425,000		20,714,026	BODY WELDING SHOP (1T3)
1.1.9	1T3-3AN5										
1.1.10	1T3-3ALL1										
1.1.11	1T4-4AN1										
1.1.12	1T4-4AN2										
1.1.13	1T4-4AN3										
1.1.14	1T4-4AN4	1	NO.		15,900,761		15,900,761	395,000		16,295,761	BODY WELDING SHOP (1T4)
1.1.15	1T4-4ALL1										
1.1.16	3T1-1AN1										
1.1.17	3T1-1AN2										
1.1.18	3T1-1AN3	1	NO.		24,497,791		24,497,791	450,000		24,947,791	G.A SHOP (3T1)
1.1.19	3T1-1AN4										
1.1.20	3T1-1AN5										
1.1.21	3T2-2AN1										
1.1.22	3T2-2AN2										
1.1.23	3T2-2AN3	1	NO.		14,906,376		14,906,376	405,000		15,311,376	G.A SHOP (3T2)
1.1.24	3T2-2AN4										




Our Ref: RSG-157570326-REV00-S01

Dated: 11-03-2026

Component Details

1- LT Panel - 1T1		Qty.	1	
Sr.	Component Details	Qty	Make	Model
Incoming				
1	4000ATP ACB Icu=100kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1240-SCE62-8JR4-Z T40
2	Auto Off Manual Selector Switch	1	Camsco	CA-111
3	Digital Energy Analyzer With RS-485 Port	1	Siemens	7KM3120-0BA01-1DA0
4	Digital Volt Meter	1	Entes/Tense	EVM-3-96/DJV-96
5	Volt Selector Switch	1	Camsco	CV-34
6	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
7	Ampere Selector Switch	1	Camsco	CA-34
8	Current Transformer 4000/5A	9	Fico/Metelx	STD
9	4P 100kA SPD Type 1 + 2	1	Phoenix	STD
10	125AFP MCCB Icu=55kA Fixed For SPD	1	Siemens	3VM1112-5GD42-0AA0
11	Indication Lights R, Y, B, On, Off, Trip	6	Schneider	XB7
12	Push Button On, Off	2	Schneider	XB7
13	6ASP MCB 6kA for Control	4	Siemens	5SL6106-7
14	20ASP MCB Icu=10kA For Fan	1	Siemens	5SL4120-7
15	16ASP MCB Icu=10kA For Lighting	1	Siemens	5SL4116-7
16	16ASP MCB Icu=10kA For TCD	1	Siemens	5SL4116-7
Outgoing				
1	1250ATP ACB Icu=66kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1112-3CE62-8JR4-Z T40
	Auto Off Manual Selector Switch	1	Camsco	CA-111
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 1500/5A	3	Fico/Metelx	STD
	Indication Lights On, Off, Trip	3	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
2	1600ATP ACB Icu=66kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1116-3CE62-8JR4-Z T40
	Auto Off Manual Selector Switch	1	Camsco	CA-111
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 1600/5A	3	Fico/Metelx	STD
	Indication Lights On, Off, Trip	3	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	1250ATP ACB Icu=66kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1112-3CE62-8JR4-Z T40
	Auto Off Manual Selector Switch	1	Camsco	CA-111



3	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 1500/5A	3	Fico/Metelx	STD
	Indication Lights On, Off, Trip	3	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
Housing Accessories				
Panel Light With Limit Switch, Exhaust Fan With Thermostat are Included				
Other Detail				
Form 4b Enclosure, IP-41 Indoor, 99.9% Tin & Sleeved Copper Bus Bar, Floor Standing Type				
2-	LT Panel - 1T3	Qty.	1	
Sr.	Component Details	Qty	Make	Model
Incoming				
1	3200ATP ACB Icu=100kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1232-5CE62-8JR4-Z T40
2	Auto Off Manual Selector Switch	1	Camsco	CA-111
3	Digital Energy Analyzer With RS-485 Port	1	Siemens	7KM3120-0BA01-1DA0
4	Digital Volt Meter	1	Entes/Tense	EVM-3-96/DJV-96
5	Volt Selector Switch	1	Camsco	CV-34
6	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
7	Ampere Selector Switch	1	Camsco	CA-34
8	Current Transformer 3200/5A	9	Fico/Metelx	STD
9	4P 100kA SPD Type 1 + 2	1	Phoenix	STD
10	125AFP MCCB Icu=55kA Fixed For SPD	1	Siemens	3VM1112-5GD42-0AA0
11	Indication Lights R, Y, B, On, Off, Trip	6	Schneider	XB7
12	Push Button On, Off	2	Schneider	XB7
13	6ASP MCB 6kA for Control	4	Siemens	5SL6106-7
14	20ASP MCB Icu=10kA For Fan	1	Siemens	5SL4120-7
15	20ASP MCB Icu=10kA For Lighting	1	Siemens	5SL4120-7
16	16ASP MCB Icu=10kA For TCD	1	Siemens	5SL4116-7
Outgoing				
1	100ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2010-5HL32-0AA0
	Aux. Switch On, Off For 3VA 100A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 100A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 100/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	2	Siemens	5SL6106-7
2	160ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2116-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 160A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 160A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 160A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96



	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 200/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
3	100ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2010-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 100A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 100A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 100A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 100/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
4	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	400ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2340-5HL32-0AA0
	Motor Mechanism @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 400A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 400/5A	3	Fico/Metelx	STD
5	Indication Lights On, Off	2	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	250ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2225-5HN32-0AA0
	Shunt Trip @ 220VAC For 3VA 250A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 250A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 250A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
6	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 250/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	250ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2225-5HN32-0AA0
	Shunt Trip @ 220VAC For 3VA 250A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 250A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 250A MCCB	1	Siemens	3VA9267-0FK21
7	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 250/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	630ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2463-5HN32-0AA0
	Motor Mechanism @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9988-0BL33
8	Aux. Switch On, Off For 3VA 630A MCCB	1	Siemens	3VA9988-0AA12




7	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
8	630ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2463-5HL32-0AA0
	Motor Mechanism @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 630A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
9	100ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2010-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 100A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 100A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 100A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 100/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
10	250ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2225-5HN32-0AA0
	Shunt Trip @ 220VAC For 3VA 250A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 250A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 250A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 250/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
11	250ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2225-5HN32-0AA0
	Shunt Trip @ 220VAC For 3VA 250A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 250A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 250A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 250/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	630ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2463-5HN32-0AA0
	Motor Mechanism @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9467-0HA20

12	Shunt Trip @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 630A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
13	400ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2340-5HN32-0AA0
	Motor Mechanism @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 400A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 400/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
14	1250ATP ACB Icu=66kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1112-3CE62-8JR4-Z T40
	Auto Off Manual Selector Switch	1	Camsco	CA-111
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 1500/5A	3	Fico/Metelx	STD
	Indication Lights On, Off, Trip	3	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
15	800ATP ACB Icu=66kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1108-3CE62-8JR4-Z T40
	Auto Off Manual Selector Switch	1	Camsco	CA-111
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off, Trip	3	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
16	3200ATP ACB Icu=66kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1232-3CE62-8JR4-Z T40
	Auto Off Manual Selector Switch	1	Camsco	CA-111
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 3200/5A	3	Fico/Metelx	STD
	Indication Lights On, Off, Trip	3	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
Housing Accessories				
Panel Light With Limit Switch, Exhaust Fan With Thermostat are Included				
Other Detail				

Form 4b Enclosure, IP-41 Indoor, 99.9% Tin & Sleeved Copper Bus Bar, Floor Standing Type				
3-	LT Panel - 1T4	Qty.	1	
Sr.	Component Details	Qty	Make	Model
Incoming				
1	2000ATP ACB Icu=100kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1220-5CE62-8JR4-Z T40
2	Auto Off Manual Selector Switch	1	Camsco	CA-111
3	Digital Energy Analyzer With RS-485 Port	1	Siemens	7KM3120-0BA01-1DA0
4	Digital Volt Meter	1	Entes/Tense	EVM-3-96/DJV-96
5	Volt Selector Switch	1	Camsco	CV-34
6	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
7	Ampere Selector Switch	1	Camsco	CA-34
8	Current Transformer 2000/5A	9	Fico/Metelx	STD
9	4P 100kA SPD Type 1 + 2	1	Phoenix	STD
10	125AFP MCCB Icu=55kA Fixed For SPD	1	Siemens	3VM1112-5GD42-0AA0
11	Indication Lights R, Y, B, On, Off, Trip	6	Schneider	XB7
12	Push Button On, Off	2	Schneider	XB7
13	6ASP MCB 6kA for Control	4	Siemens	5SL6106-7
14	20ASP MCB Icu=10kA For Fan	1	Siemens	5SL4120-7
15	16ASP MCB Icu=10kA For Lighting	1	Siemens	5SL4116-7
16	16ASP MCB Icu=10kA For TCD	1	Siemens	5SL4116-7
Outgoing				
1	160ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2116-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 160A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 160A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 160A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 200/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
2	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	100ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2010-5HN32-0AA0
	Shunt Trip @ 220VAC For 3VA 100A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 100A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 100A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 100/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	100ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2010-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 100A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 100A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 100A MCCB	1	Siemens	3VA9267-0FK21



3	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 100/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
4	630ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2463-5HL32-0AA0
	Motor Mechanism @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 630A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
5	100ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2010-5HN32-0AA0
	Shunt Trip @ 220VAC For 3VA 100A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 100A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 100A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 100/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
6	250ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2225-5HN32-0AA0
	Shunt Trip @ 220VAC For 3VA 250A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 250A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 250A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 250/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
7	400ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2340-5HN32-0AA0
	Motor Mechanism @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 400A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 400/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	800ATP ACB Icu=66kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1108-3CE62-8JR4-Z T40
	Auto Off Manual Selector Switch	1	Camsco	CA-111




8	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off, Trip	3	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
9	400ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2340-5HL32-0AA0
	Motor Mechanism @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 400A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 400/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
10	400ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2340-5HN32-0AA0
	Motor Mechanism @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 400A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 400/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
11	800ATP ACB Icu=66kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1108-3CE62-8JR4-Z T40
	Auto Off Manual Selector Switch	1	Camsco	CA-111
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off, Trip	3	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
12	630ATP MCCB Icu=55kA ADJ. LSI, Fixed Mounted Type	1	Siemens	3VA2463-5HN32-0AA0
	Motor Mechanism @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 630A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
12	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	2000ATP ACB Icu=66kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1220-3CE62-8JR4-Z T40




13	Auto Off Manual Selector Switch	1	Camsco	CA-111
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 2000/5A	3	Fico/Metelx	STD
	Indication Lights On, Off, Trip	3	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
Housing Accessories				
Panel Light With Limit Switch, Exhaust Fan With Thermostat are Included				
Other Detail				
Form 4b Enclosure, IP-41 Indoor, 99.9% Tin & Sleeved Copper Bus Bar, Floor Standing Type				
4-	LT Panel - 3T1	Qty.	1	
Sr.	Component Details	Qty	Make	Model
Incoming				
1	4000ATP ACB Icu=100kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1240-5CE62-8JR4-Z T40
2	Auto Off Manual Selector Switch	1	Camsco	CA-111
3	Digital Energy Analyzer With RS-485 Port	1	Siemens	7KM3120-0BA01-1DA0
4	Digital Volt Meter	1	Entes/Tense	EVM-3-96/DJV-96
5	Volt Selector Switch	1	Camsco	CV-34
6	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
7	Ampere Selector Switch	1	Camsco	CA-34
8	Current Transformer 4000/5A	9	Fico/Metelx	STD
9	4P 100kA SPD Type 1 + 2	1	Phoenix	STD
10	125AFP MCCB Icu=55kA Fixed For SPD	1	Siemens	3VM1112-5GD42-0AA0
11	Indication Lights R, Y, B, On, Off, Trip	6	Schneider	XB7
12	Push Button On, Off	2	Schneider	XB7
13	6ASP MCB 6kA for Control	4	Siemens	5SL6106-7
14	20ASP MCB Icu=10kA For Fan	1	Siemens	5SL4120-7
15	16ASP MCB Icu=10kA For Lighting	1	Siemens	5SL4116-7
16	16ASP MCB Icu=10kA For TCD	1	Siemens	5SL4116-7
Outgoing				
1	250ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2225-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 250A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 250A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 250A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 250/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	160ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2116-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 160A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 160A MCCB	1	Siemens	3VA9988-0AA12

2	Ext. Rotary Handle For 3VA 160A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 150/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
3	400ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2340-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 400A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 400A MCCB	1	Siemens	3VA9467-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 400/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
4	250ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2225-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 250A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 250A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 250A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 250/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
5	400ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2340-5HL32-0AA0
	Earth Leakage Relay	1	Schneider	RH99M
	Toroid CT 200mm Dia	1	Metelx	STD
	Motor Mechanism @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 400A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 400A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 400/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
6	630ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2463-5HL32-0AA0
	Motor Mechanism @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 630A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7



	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
7	800ATP ACB Icu=66kA ADJ. ISI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1108-3CE62-8JR4-Z T40
	Auto Off Manual Selector Switch	1	Camsco	CA-111
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off, Trip	3	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
8	160ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2116-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 160A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 160A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 160A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 150/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
9	630ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2463-5HL32-0AA0
	Motor Mechanism @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 630A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
10	160ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2116-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 160A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 160A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 160A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 150/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
11	63ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2063-5HL32-0AA0
	Aux. Switch On, Off For 3VA 63A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 63A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 150/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	2	Siemens	5SL6106-7



12	63ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2063-5HL32-0AA0
	Aux. Switch On, Off For 3VA 63A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 63A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 150/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	2	Siemens	5SL6106-7
13	800ATP ACB Icu=66kA ADJ. LSI, Drawout Type, Complete Motorized With UVT	1	Siemens	3WA1108-3CE62-8JR4-Z T40
	Auto Off Manual Selector Switch	1	Camsco	CA-111
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off, Trip	3	Schneider	XB7
	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
14	160ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2116-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 160A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 160A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 160A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 150/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
15	250ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2225-5HL32-0AA0
	Shunt Trip @ 220VAC For 3VA 250A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 250A MCCB	1	Siemens	3VA9988-0AA12
	Ext. Rotary Handle For 3VA 250A MCCB	1	Siemens	3VA9267-0FK21
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 250/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
16	630ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2463-5HL32-0AA0
	Motor Mechanism @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9467-0HA20
	Shunt Trip @ 220VAC For 3VA 630A MCCB	1	Siemens	3VA9988-0BL33
	Aux. Switch On, Off For 3VA 630A MCCB	1	Siemens	3VA9988-0AA12
	Digital Ampere Meter	1	Entes/Tense	EPM-4D-96/DJA-96
	Ampere Selector Switch	1	Camsco	CA-34
	Current Transformer 800/5A	3	Fico/Metelx	STD
	Indication Lights On, Off	2	Schneider	XB7
16	Push Button On, Off	2	Schneider	XB7
	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	400ATP MCCB Icu=55kA ADJ. LI, Fixed Mounted Type	1	Siemens	3VA2340-5HL32-0AA0

Sr.	Component Details	Qty	Make	Model
	<u>Incoming</u>			
	<u>420kVAR PFI Plant</u>			
1	800ATP Load Break Switch With Direct Handle	1	Siemens	3KD4832-0QE10-0
2	PF Controller (3-Phase)	1	Circutor/Klemsan/Eqv.	-
3	4P 40kA SPD Type 2	1	Phoenix	STD
4	63AFP MCCB Icu=55kA Fixed For SPD	1	Siemens	3VM1163-5GD42-0AA0
	<u>60kVAR Step</u>	7		
5	Magnetic Contactor for Capacitor Switching 50kVAR	7	Siemens	3RT2636-1AP03
	HRC Fuse 125A	21	Sigma/Eqv.	NH00
	Box 125A	7	Sigma/Eqv.	NH00
	50kVAR Harmonic Filter Reactor With 14%	7	Circutor/Irhajhus/Eqv.	RBZ-60-400
	40kVAR Capacitors @ 525VAC	14	Circutor/Irhajhus/Eqv.	52/40
6	Push Button On, Off	14	Schneider	XB7
7	Indication Lights On, Off	14	Schneider	XB7
8	Aux. Control Relay 3NO + 2NC	3	Schneider	CAD32M7
9	Aux. Contact 1NO + 3NC	1	Schneider	LADN13
10	Auto Off Manual Selector Switch	1	Camsco	CA-111
11	Current Transformer 2000/5A	3	Fico/Metelx	STD
12	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
	<u>Housing Accessories</u>			
	<i>Panel Light With Limit Switch, Exhaust Fan With Thermostat are Included</i>			
	<u>Other Detail</u>			
	<i>Form 1 Enclosure, IP-41 Indoor, 99.9% Tin & Sleeved Copper Bus Bar, Floor Standing Type</i>			
7-	1T3-3ACC1 & 1T3-3ACC2 (315 KVAR)	Qty. 2		
Sr.	Component Details	Qty	Make	Model
	<u>Incoming</u>			
	<u>330kVAR PFI Plant</u>			
1	630ATP Load Break Switch With Direct Handle	1	Siemens	3KD4632-0QE10-0
2	PF Controller (3-Phase)	1	Circutor/Klemsan/Eqv.	-
3	4P 40kA SPD Type 2	1	Phoenix	STD
4	63AFP MCCB Icu=55kA Fixed For SPD	1	Siemens	3VM1163-5GD42-0AA0
	<u>40kVAR Step</u>	8		
5	Magnetic Contactor for Capacitor Switching 50kVAR	8	Siemens	3RT2636-1AP03
	HRC Fuse 125A	24	Sigma/Eqv.	NH00
	Box 125A	8	Sigma/Eqv.	NH00
	40kVAR Harmonic Filter Reactor With 7%	8	Circutor/Irhajhus/Eqv.	RBZ-40-400
	25kVAR Capacitors @ 460VAC	16	Circutor/Irhajhus/Eqv.	46/25
7	Push Button On, Off	16	Schneider	XB7
8	Indication Lights On, Off	16	Schneider	XB7
9	Aux. Control Relay 3NO + 2NC	3	Schneider	CAD32M7
10	Aux. Contact 1NO + 3NC	1	Schneider	LADN13
11	Auto Off Manual Selector Switch	1	Camsco	CA-111



5	HRC Fuse 125A	24	Sigma/Eqv.	NH00
	Box 125A	8	Sigma/Eqv.	NH00
	40kVAR Harmonic Filter Reactor With 7%	8	Circutor/Irhajhus/Eqv.	RBZ-40-400
	25kVAR Capacitors @ 460VAC	16	Circutor/Irhajhus/Eqv.	46/25
7	Push Button On, Off	16	Schneider	XB7
8	Indication Lights On, Off	16	Schneider	XB7
9	Aux. Control Relay 3NO + 2NC	3	Schneider	CAD32M7
10	Aux. Contact 1NO + 3NC	1	Schneider	LADN13
11	Auto Off Manual Selector Switch	1	Camsco	CA-111
12	Current Transformer 2000/5A	3	Fico/Metelx	STD
13	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
Housing Accessories				
Panel Light With Limit Switch, Exhaust Fan With Thermostat are Included				
Other Detail				
Form 1 Enclosure, IP-41 Indoor, 99.9% Tin & Sleeved Copper Bus Bar, Floor Standing Type				
10-	3T2-2ACC1 (180 KVAR)	Qty.	1	
Sr.	Component Details	Qty	Make	Model
Incoming				
187.5kVAR PFI Plant				
1	400ATP Load Break Switch With Direct Handle	1	Siemens	3KD4232-OPE10-0
2	PF Controller (3-Phase)	1	Circutor/Klemsan/Eqv.	
3	4P 40kA SPD Type 2	1	Phoenix	STD
4	63AFP MCCB Icu=55kA Fixed For SPD	1	Siemens	3VM1163-5GD42-0AA0
40kVAR Step		5		
5	Magnetic Contactor for Capacitor Switching 50kVAR	5	Siemens	3RT2636-1AP03
	HRC Fuse 125A	15	Sigma/Eqv.	NH00
	Box 125A	5	Sigma/Eqv.	NH00
	40kVAR Harmonic Filter Reactor With 7%	5	Circutor/Irhajhus/Eqv.	RBZ-40-400
25kVAR Capacitors @ 460VAC		10	Circutor/Irhajhus/Eqv.	46/25
7	Push Button On, Off	8	Schneider	XB7
8	Indication Lights On, Off	8	Schneider	XB7
9	Aux. Control Relay 3NO + 2NC	1	Schneider	CAD32M7
10	Aux. Contact 1NO + 3NC	1	Schneider	LADN13
11	Auto Off Manual Selector Switch	1	Camsco	CA-111
12	Current Transformer 2000/5A	3	Fico/Metelx	STD
13	6ASP MCB 6kA for Control	3	Siemens	5SL6106-7
Housing Accessories				
Panel Light With Limit Switch, Exhaust Fan With Thermostat are Included				
Other Detail				
Form 1 Enclosure, IP-41 Indoor, 99.9% Tin & Sleeved Copper Bus Bar, Floor Standing Type				