

EnEfG — Energieeffizienzgesetz

Audit support + Umsetzungsplan

Year 2025

SCOPE — TOTAL FINAL ENERGY VS ENEFG THRESHOLDS

TOTAL ENERGY

0.42 GWh

portfolio final energy / yr

IMPLEMENTATION PLAN (§9)

Not required

> 2.5 GWh

ENERGY AUDIT (§8)

Not required

> 2.77 GWh — DIN EN 16247

ENMS / ISO 50001

Not required

> 23.6 GWh

This portfolio is below **2.5 GWh/yr**, so the EnEfG audit / plan duties do not currently apply. The measures below are still a voluntary efficiency roadmap.

EnEfG enforcement is by BAFA (a nationwide control wave began March 2026). The first audit under the new rules is due by ~11 Oct 2026; the implementation plan must be published within three months of the audit / certification and is externally reviewed.

IMPLEMENTATION PLAN (UMSETZUNGSPLAN) — ECONOMIC MEASURES

ECONOMIC MEASURES

1

NPV-positive

ANNUAL SAVING

€3,275

€/yr (sum)

INVESTMENT

€36,000

net capex (sum)

CO₂ SAVING

6 t

tCO₂e/yr (sum)

Figures sum independent per-measure estimates; overlapping measures are capped to a realistic share of actual energy cost and emissions, so totals are indicative, not strictly additive.

MEASURE	BUILDING	SAVING €/YR	CO ₂ T/YR	NET CAPEX	PAYBACK	NPV
Implement HVAC Scheduling & Setback EnEfG / EPBD — Operational Efficiency	Berliner Bürogebäude Alpha	€3,275	6	€36,000	11.0 yr	€3,300

5 further measures were assessed but are not currently economic ($NPV \leq 0$) and are therefore excluded from the plan. BAFA sample-checks the non-economic exclusions, so retain the assessment.

EnEfG §8/§9 support. A measure is treated as economic when its net present value is positive (proxy for the legal test: NPV positive within 50% of the useful life). The per-measure end-energy (kWh) saving and the formal audit are part of a DIN EN 16247 audit by a qualified auditor; this document is the measure basis + economics, not the completed audit, and is not legal advice.

