
1 Plan 1:20

Solid: visible furniture · light dashes: overhead · FFL: finished floor = 0
Opening envelopes: Clearance view · exact construction sizes: Cabinet details



Dimensions in mm · verify on site · see Cabinet schedule and Review issues

K1, K19, K3, K5, K7, K9, K11, K17, K15, K13


Project
Cabinets design

Drawing	Sheet
Plan	1 of 6

Scale	Units	Date
1:20	millimetres	10/20/2026

2 Upper cabinet plan 1:20

Upper units only · elevations show exact mounting levels · dimensions in mm



Dimensions in mm · verify on site · see Cabinet schedule and Review issues

K2, K4, K6, K8, K10, K12, K18, K16, K14


Project
Cabinets design

Drawing	Sheet
Upper cabinet plan	2 of 6

Scale	Units	Date
1:20	millimetres	10/20/2026

3 Elevation A 1:20

Reference height chains are identified on the view · FFL = 0 · each cabinet has an exact detail sheet



Dimensions in mm · verify on site · see Cabinet schedule and Review issues

K1, K2, K19, K3, K4, K5, K6, K7, K8, K9, K10, K11, K12

K1 opening envelope meets K13

K2 opening envelope meets K14

Project

Cabinets design


Drawing	Sheet
Elevation A	3 of 6

Scale	Units	Date
1:20	millimetres	10/20/2026

4 Elevation B 1:20

Reference height chains are identified on the view · FFL = 0 · each cabinet has an exact detail sheet

Reference stack: K17 + K18 · FFL 0



Dimensions in mm · verify on site · see Cabinet schedule and Review issues

K17, K18, K15, K16, K13, K14

Project
Cabinets design

Drawing	Sheet
Elevation B	4 of 6

Scale	Units	Date
1:20	millimetres	10/20/2026

5 Cabinet schedule

Mark	Cabinet	W × H × D (mm)	Location
K1	Base cabinet	600 × 860 × 580	Wall A
K2	Wall cabinet	600 × 700 × 350	Wall A, underside 1420
K19	Sink	800 × 300 × 500	Wall A, on the worktop
K3	Base cabinet	600 × 860 × 580	Wall A
K4	Wall cabinet	600 × 700 × 350	Wall A, underside 1421
K5	Base cabinet	600 × 860 × 580	Wall A
K6	Wall cabinet	600 × 700 × 350	Wall A, underside 1420
K7	Base cabinet	600 × 860 × 580	Wall A
K8	Wall cabinet	600 × 700 × 350	Wall A, underside 1420
K9	Tall cabinet	600 × 2150 × 580	Wall A
K10	Wall cabinet	600 × 700 × 350	Wall A, underside 2150
K11	Tall cabinet	600 × 2150 × 580	Wall A
K12	Wall cabinet	600 × 700 × 350	Wall A, underside 2150
K17	Base cabinet	600 × 860 × 580	Wall B
K18	Wall cabinet	600 × 700 × 350	Wall B, underside 1420
K15	Base cabinet	600 × 860 × 580	Wall B
K16	Wall cabinet	600 × 700 × 350	Wall B, underside 1420
K13	Base cabinet	600 × 860 × 580	Wall B
K14	Wall cabinet	600 × 700 × 350	Wall B, underside 1420

Identifiers remain stable when furniture moves. Heights and undersides are measured from finished floor.

6 Review issues

Type	Elements	Finding	Rule / reference
alignment	K2, K4	K2 / K4: undersides differ by 1 mm	Placement review: differences below 5 mm
alignment	K4, K6	K4 / K6: undersides differ by 1 mm	Placement review: differences below 5 mm
operation	K1, K13	K1 opening envelope meets K13	Opening envelope against static geometry
operation	K2, K14	K2 opening envelope meets K14	Opening envelope against static geometry
simultaneous	K1, K13	K1 / K13: opening envelopes intersect during simultaneous use	Simultaneous moving-front envelope review
simultaneous	K2, K14	K2 / K14: opening envelopes intersect during simultaneous use	Simultaneous moving-front envelope review
simultaneous	K3, K13	K3 / K13: opening envelopes intersect during simultaneous use	Simultaneous moving-front envelope review
simultaneous	K4, K14	K4 / K14: opening envelopes intersect during simultaneous use	Simultaneous moving-front envelope review

Review recommendations separately from confirmed geometry conflicts.