

Cybersecurity Standards Research

Applicable Standards for Advanced Threat Monitoring in RobotLab

Fontys University of Applied Sciences

Course:	AV-CSP-AV-CSP1
Authors:	Team 5
Date:	September 16, 2026

Version History

Version	Date	Description
0.1	September 16, 2026	Initial Draft
0.2	September 16, 2026	Added Dutch and national standards (BIO2, Cyberbeveiligingswet/NIS2, NCSC OT/IACS guidance)

Contents

Version History	1
1 Introduction	4
2 Scope of Applicability	4
3 Applicable Standards and Frameworks	5
3.1 NIST SP 800-137 - Information Security Continuous Monitoring	5
3.1.1 Overview	5
3.1.2 Relevance to the Project	5
3.1.3 Application in the Project	5
3.2 NIST SP 800-94 - Guide to Intrusion Detection and Prevention Systems . .	5
3.2.1 Overview	5
3.2.2 Relevance to the Project	5
3.2.3 Application in the Project	6
3.3 CIS Controls v8	6
3.3.1 Overview	6
3.3.2 Relevance to the Project	6
3.3.3 Application in the Project	6
3.4 MITRE ATT&CK Framework	7
3.4.1 Overview	7

3.4.2	Relevance to the Project	7
3.4.3	Application in the Project	7
3.5	ISO/IEC 27035 - Information Security Incident Management	7
3.5.1	Overview	7
3.5.2	Relevance to the Project	7
3.5.3	Application in the Project	8
3.6	NIST SP 800-190 - Application Container Security Guide	8
3.6.1	Overview	8
3.6.2	Relevance to the Project	8
3.6.3	Application in the Project	8
3.7	ISO/IEC 27001 - Annex A Controls (Monitoring-Related)	8
3.7.1	Overview	8
3.7.2	Relevance to the Project	9
3.7.3	Application in the Project	9
3.8	IEC 62443 - Industrial Automation and Control Systems Security	9
3.8.1	Overview	9
3.8.2	Relevance to the Project	9
3.8.3	Application in the Project	10
3.9	NIST SP 800-82 - Guide to Operational Technology Security	10
3.9.1	Overview	10
3.9.2	Relevance to the Project	10
3.9.3	Application in the Project	10
4	Dutch and National Standards	11
4.1	Baseline Informatiebeveiliging Overheid 2 (BIO2)	11
4.1.1	Overview	11
4.1.2	Relevance to the Project	11
4.1.3	Application in the Project	12
4.2	Cyberbeveiligingswet (Cbw) - Dutch Implementation of NIS2	12
4.2.1	Overview	12

4.2.2	Relevance to the Project	12
4.2.3	Application in the Project	12
4.3	NCSC Guidance on OT/IACS Monitoring	13
4.3.1	Overview	13
4.3.2	Relevance to the Project	13
4.3.3	Application in the Project	13
4.4	Additional Dutch References	13
5	Standards Mapping to Research Questions	14
6	How Standards Will Be Applied	15
7	Conclusion	15

1 Introduction

This document identifies and analyses the cybersecurity standards that are applicable to the Advanced Threat Monitoring project for RobotLab. As the project aims to design and implement an advanced monitoring architecture integrating Host-based Intrusion Detection Systems (HIDS), Network-based Intrusion Detection Systems (NIDS), and Software-Defined Networking (SDN) mechanisms, it is important to ground the technical decisions in recognised industry standards and frameworks.

The purpose of this document is to provide an overview of the most relevant standards, explain how each one relates to the project scope, and describe how they will be applied throughout the research, design, and implementation phases. By aligning the project with established standards, the resulting architecture will be more rigorous, auditable, and comparable to industry best practices. In addition to the internationally recognised standards, this document considers the Dutch national standards and legislation that apply to the project given its context as work carried out at a Dutch publicly funded university of applied sciences.

2 Scope of Applicability

The standards covered in this document are selected based on their relevance to the following aspects of the RobotLab project:

- Continuous security monitoring in cloud and on-premises environments
- Intrusion detection and prevention system design
- Container and Kubernetes runtime security
- Security incident detection, response, and containment
- Log management, event correlation, and SIEM architecture
- Mapping detection coverage to known attack techniques
- Compliance with applicable Dutch national standards and legislation

Standards that relate only to governance, compliance audit, or infrastructure topics outside the monitoring scope are considered out of scope for this document.

3 Applicable Standards and Frameworks

3.1 NIST SP 800-137 - Information Security Continuous Monitoring

3.1.1 Overview

NIST Special Publication 800-137 defines a framework for establishing an information security continuous monitoring (ISCM) programme. It provides guidance on defining metrics, implementing monitoring solutions, analysing data, and responding to findings.

3.1.2 Relevance to the Project

The core objective of RobotLab’s monitoring project, in way provide deeper, continuous visibility into infrastructure behaviour, which directly corresponds to the ISCM model defined in SP 800-137. The publication’s emphasis on automating data collection, establishing monitoring tiers (organisation, mission/business process, and information system levels), and integrating monitoring with incident response is directly applicable to the reference architecture being designed.

3.1.3 Application in the Project

- Used to structure the monitoring tiers in the reference architecture.
- Informs the metrics and coverage criteria used to validate whether the monitoring system provides sufficient visibility.
- Provides a baseline definition of what continuous monitoring means in the context of cloud and hybrid environments.

3.2 NIST SP 800-94 - Guide to Intrusion Detection and Prevention Systems

3.2.1 Overview

NIST SP 800-94 provides comprehensive guidance on the design, deployment, and management of Intrusion Detection and Prevention Systems (IDPS). It covers network-based, host-based, and hybrid approaches, and describes detection methodologies including signature-based, anomaly-based, and stateful protocol analysis.

3.2.2 Relevance to the Project

The main research question of this project is explicitly focused on integrating HIDS and NIDS components. SP 800-94 provides the theoretical and architectural foundation for

understanding the differences, strengths, and limitations of each detection approach, and how they can be combined effectively.

3.2.3 Application in the Project

- Serves as the primary reference for the HIDS/NIDS design decisions in Sub Questions 1 and 5.
- Informs the selection and comparison of tools such as Suricata (NIDS), Zeek (NIDS), and Falco (HIDS).
- Provides the detection methodology taxonomy used in the tool comparison matrix.

3.3 CIS Controls v8

3.3.1 Overview

The Center for Internet Security (CIS) Controls v8 defines a prioritised set of security actions designed to mitigate the most common attack vectors. Control Group 8 (Audit Log Management), Control Group 13 (Network Monitoring and Defence), and Control Group 10 (Malware Defenses) are of particular relevance.

3.3.2 Relevance to the Project

CIS Controls offer a practical, implementation-oriented complement to the more framework-level guidance of NIST publications. The specific controls around network monitoring, log retention, and alerting thresholds map directly to the implementation and testing phases of this project.

3.3.3 Application in the Project

- CG 8 (Audit Log Management) informs the log pipeline design and retention policies in the monitoring architecture.
- CG 13 (Network Monitoring and Defence) provides implementation safeguards against which the NIDS component can be evaluated.
- Used as a practical checklist during the validation phase to verify that the implementation covers expected monitoring baseline behaviours.

3.4 MITRE ATT&CK Framework

3.4.1 Overview

The MITRE ATT&CK framework is a globally recognised knowledge base of adversary tactics, techniques, and procedures (TTPs), based on real-world observations. It is structured across multiple matrices, including Enterprise, Cloud, and Containers.

3.4.2 Relevance to the Project

The validation strategy defined in the Research Plan explicitly calls for mapping detection coverage against a threat framework. ATT&CK is the industry standard for this purpose and is directly applicable to the cloud and container context of RobotLab.

3.4.3 Application in the Project

- Used in the Detection Coverage Analysis validation step to document which ATT&CK techniques are detected, partially detected, or missed by the implemented monitoring system.
- Informs the controlled attack simulation scenarios defined in Sub Question 4.
- Provides the attack surface enumeration basis for identifying which threats are most relevant to the RobotLab environment.

3.5 ISO/IEC 27035 - Information Security Incident Management

3.5.1 Overview

ISO/IEC 27035 defines a structured process for planning and managing information security incidents. It covers detection, reporting, assessment, response, and lessons learned across two parts: principles of incident management (Part 1) and guidelines for incident response (Part 2).

3.5.2 Relevance to the Project

Sub Question 2 specifically asks how the monitoring system can automatically respond to detected threats in order to contain attacks and minimise damage. ISO/IEC 27035 provides the process model within which automated and manual response actions should be structured.

3.5.3 Application in the Project

- Informs the automated response workflow design, particularly the containment and escalation steps triggered by the SDN control plane.
- Provides the incident lifecycle model used to evaluate whether the system's response capabilities address the full detection-to-containment cycle.
- Used to define the scope and expected outputs of the incident response component in the reference architecture.

3.6 NIST SP 800-190 - Application Container Security Guide

3.6.1 Overview

NIST SP 800-190 addresses security risks associated with container technologies, including image vulnerabilities, container runtime threats, host operating system exposure, and orchestration platform security (specifically Kubernetes). It provides guidance on security controls at each layer of the container stack.

3.6.2 Relevance to the Project

RobotLab's infrastructure runs on Kubernetes, and one of the identified gaps in the current monitoring setup is the lack of visibility into Kubernetes runtime behaviour. SP 800-190 directly addresses this gap and provides guidance on the use of runtime monitoring tools such as Falco.

3.6.3 Application in the Project

- Used to identify the specific monitoring requirements for the container and Kubernetes layers, informing Sub Question 1.
- Provides the container security risk model used in the infrastructure analysis phase.
- Informs the eBPF-based runtime monitoring design, particularly in relation to container escape and lateral movement detection.

3.7 ISO/IEC 27001 - Annex A Controls (Monitoring-Related)

3.7.1 Overview

ISO/IEC 27001 is the international standard for Information Security Management Systems (ISMS). While the full standard covers a broad governance scope, Annex A contains

specific technical controls directly relevant to monitoring: A.8.15 (Logging), A.8.16 (Monitoring Activities), and A.8.20 (Networks Security).

3.7.2 Relevance to the Project

Although a full ISO/IEC 27001 implementation is outside the scope of this project, the Annex A controls relevant to monitoring provide a widely accepted baseline for what a monitoring system must log, retain, and alert on. This makes them useful both for validating the architecture and for framing recommendations.

3.7.3 Application in the Project

- A.8.15 and A.8.16 inform the minimum logging and alerting requirements for the monitoring architecture.
- A.8.20 is applied during the infrastructure analysis to assess existing network security visibility gaps.
- Used in the final evaluation phase to frame the project outcomes in terms of a recognisable compliance baseline.

3.8 IEC 62443 - Industrial Automation and Control Systems Security

3.8.1 Overview

IEC 62443 is the international standard series for the security of Industrial Automation and Control Systems (IACS). It defines requirements and processes for both asset owners and system integrators across a layered model of zones and conduits. The most relevant parts for this project are IEC 62443-2-1 (security management system requirements), IEC 62443-3-3 (system-level security requirements), and IEC 62443-4-2 (component-level security requirements). In the Netherlands this series is adopted as the harmonised standard NEN-EN-IEC 62443, and the NCSC explicitly references it as the foundational standard for establishing an OT security policy.

3.8.2 Relevance to the Project

The RobotLab environment includes an orchestrator communicating with physical instruments over a command/result interface, which constitutes a control system topology within the scope of IEC 62443. The standard's zone-and-conduit model provides a structured basis for separating the IT monitoring plane (AWS, Kubernetes) from the OT control plane (orchestrator, instruments, lab facility data), and for defining security requirements at each boundary.

3.8.3 *Application in the Project*

- IEC 62443-3-3 system requirements (SR 6.1, SR 6.2) inform the monitoring and audit log requirements for the orchestrator and instrument communication channel.
- The zone-and-conduit model is used to define the boundary between the IT and OT segments in the reference architecture, ensuring monitoring coverage spans both.
- IEC 62443-2-1 informs the operational security management process for the lab environment, complementing the incident response model from ISO/IEC 27035.

3.9 NIST SP 800-82 - Guide to Operational Technology Security

3.9.1 *Overview*

NIST Special Publication 800-82 provides guidance on applying the NIST Cybersecurity Framework and security controls specifically to Operational Technology (OT) environments, including Industrial Control Systems (ICS), SCADA systems, and laboratory automation systems. It addresses the unique availability, safety, and timing constraints that differentiate OT security from traditional IT security.

3.9.2 *Relevance to the Project*

The RobotLab architecture includes a lab facility providing environmental data, physical instruments operated via the orchestrator, and a Grafana-based monitoring interface for user/manager visibility. This hybrid IT/OT topology introduces monitoring challenges not covered by the IT-focused standards already identified. SP 800-82 specifically addresses continuous monitoring for OT environments where availability and physical safety constraints limit the applicability of standard IT intrusion detection approaches.

3.9.3 *Application in the Project*

- Informs the monitoring strategy for the orchestrator-to-instrument communication plane, where availability constraints may limit the aggressiveness of active detection techniques.
- Provides OT-specific incident response guidance to complement ISO/IEC 27035, particularly for scenarios where automated containment (e.g. SDN-based isolation) could impact physical lab operations.
- Used to define the monitoring boundary between the IT layer (Kubernetes, AWS) and the OT layer (instruments, lab facility), ensuring both are covered in the reference architecture.

- Informs risk analysis entries related to the physical instrument control plane, where a compromised orchestrator could have physical consequences.

4 Dutch and National Standards

Because this project is carried out at a Dutch publicly funded university of applied sciences, it operates within a national standards and legislative context in addition to the international standards described above. The standards in this section are selected for their direct relevance to monitoring, detection, incident response, and the hybrid IT/OT character of RobotLab. They do not replace the international standards but rather express, extend, or give legal force to the same monitoring and incident-handling requirements within the Dutch context.

4.1 Baseline Informatiebeveiliging Overheid 2 (BIO2)

4.1.1 *Overview*

The Baseline Informatiebeveiliging Overheid (BIO) is the common information security baseline for all layers of Dutch government. Its current version, BIO2 (version 1.3), was published in the *Staatscourant* on 5 March 2026 and succeeds the previous BIO v1.04. BIO2 is structured according to NEN-EN-ISO/IEC 27001:2023 and NEN-EN-ISO/IEC 27002:2022, replaces the previous three fixed Basic Security Levels (*Basisbeveiligingsniveaus*) with a risk-based approach, and has been strengthened to align with the requirements arising from the NIS2 directive. For the central government, provinces, and water authorities it applies as mandatory self-regulation, and it is directional for municipalities.

4.1.2 *Relevance to the Project*

As a publicly funded institution, Fontys operates within the same national information security context that BIO2 defines. Because BIO2 follows the structure and controls of NEN-EN-ISO/IEC 27002:2022, it directly incorporates the monitoring-related controls 8.15 (Logging), 8.16 (Monitoring activities), and 8.20 (Networks security). BIO2 therefore provides the Dutch-context operationalisation of the same logging and monitoring baseline that this project already references through ISO/IEC 27001 Annex A, while adding a national risk-management framing.

4.1.3 Application in the Project

- Provides the Dutch national baseline for the minimum logging, monitoring, and alerting requirements of the reference architecture.
- Its risk-based approach informs the selection of additional monitoring measures beyond the baseline controls.
- Used in the evaluation phase to frame the project outcomes against a recognisable Dutch compliance baseline that maps cleanly onto the ISO/IEC 27002:2022 controls already identified.

4.2 Cyberbeveiligingswet (Cbw) - Dutch Implementation of NIS2

4.2.1 Overview

The Cyberbeveiligingswet (Cbw) is the Dutch transposition of the European NIS2 directive, replacing the existing Wet beveiliging netwerk- en informatiesystemen (Wbni). The bill was adopted by the House of Representatives (Tweede Kamer) on 15 April 2026 and, at the time of writing, awaits approval by the Senate (Eerste Kamer), with entry into force expected around 1 July 2026. The Cbw introduces a duty of care (zorgplicht), an incident reporting duty (meldplicht), and a registration duty (registratieplicht). Notably, the Netherlands extended the scope beyond the NIS2 minimum to explicitly include higher education – universities and universities of applied sciences – as well as local and regional government.

4.2.2 Relevance to the Project

Because the Dutch implementation explicitly brings universities of applied sciences within scope, the Cbw is directly relevant to a Fontys project. The duty of care and incident reporting duty create concrete drivers for precisely the capability this monitoring architecture is intended to provide: continuous monitoring to support the duty of care, and timely, reliable incident detection to support the reporting obligation. The Cbw thus provides a legislative motivation for the project that complements the process-level guidance of ISO/IEC 27035.

4.2.3 Application in the Project

- Provides the legal and regulatory framing for the monitoring and incident-response requirements addressed in Sub Questions 2 and 4.
- The incident reporting duty (meldplicht) informs the detection-to-reporting timeline that the automated response workflow must support.

- Complements ISO/IEC 27035 by supplying the national legal basis for the incident detection and handling capabilities of the reference architecture.

4.3 NCSC Guidance on OT/IACS Monitoring

4.3.1 Overview

The Nationaal Cyber Security Centrum (NCSC) is the Dutch national authority for cybersecurity and publishes practical national-context guidance for securing Operational Technology and Industrial Automation and Control Systems (OT/IACS). This guidance recommends applying Monitoring, Detection, and Response (MDR) passively within OT networks – for example through port mirroring or data replication – so that monitoring does not disrupt operational continuity or physical safety. It references IEC 62443 as the foundational standard for OT security policy.

4.3.2 Relevance to the Project

The NCSC guidance is the Dutch national-context counterpart to the OT-safe monitoring constraints this project already derives from NIST SP 800-82 and IEC 62443. RobotLab's orchestrator-to-instrument communication plane is exactly the kind of availability- and safety-sensitive OT segment for which the NCSC prescribes passive, out-of-band monitoring rather than active inline interception.

4.3.3 Application in the Project

- Informs the passive (out-of-band) monitoring approach adopted for the OT plane, using techniques such as port mirroring rather than inline interception.
- Reinforces the constraint that automated containment (e.g. SDN-based isolation) must not jeopardise physical lab operations or safety.
- Provides a nationally recognised practical reference for the OT detection design in Sub Questions 1, 2, and 3.

4.4 Additional Dutch References

Two further Dutch references are noted for completeness. The NCSC and AIVD jointly published a *Handreiking voor implementatie van detectie-oplossingen* (Guide to Implementing Detection Solutions), which sets out a risk- and impact-driven process for scoping detection – first identifying and classifying assets, then defining what is to be detected before moving to analysis and design. This publication is no longer actively maintained by the NCSC, but it remains a useful national-context process reference for the design

and validation phases of a detection system. In addition, the *Cybersecurity Implementatierichtlijn* (CSIR) for the security of Operational Technology is referenced by the Dutch government as a standard organisations may select to secure OT environments, and is noted here as a complementary national OT reference alongside NEN-EN-IEC 62443.

5 Standards Mapping to Research Questions

The table below provides a concise overview of how each standard maps to the sub questions defined in the Research Plan.

Standard	Applicable Sub Questions
NIST SP 800-137	SQ1 (monitoring methods), SQ3 (layering), SQ5 (data correlation)
NIST SP 800-94	SQ1 (kernel visibility, DPI), SQ3 (defense layers), SQ5 (HIDS/NIDS correlation)
CIS Controls v8	SQ1 (monitoring implementation), SQ3 (defense layering), SQ4 (validation)
ISO/IEC 27035	SQ2 (automated response), SQ4 (containment validation)
NIST SP 800-190	SQ1 (container runtime monitoring), SQ3 (defense layers in Kubernetes)
ISO/IEC 27001 Annex A	SQ3 (defense structure), SQ5 (logging and alerting baselines)
IEC 62443 (2-1, 3-3, 4-2)	SQ1 (OT monitoring methods), SQ2 (automated response constraints in OT), SQ3 (IT/OT zone separation)
NIST SP 800-82	SQ1 (OT visibility), SQ2 (OT-safe containment), SQ3 (hybrid IT/OT layers), SQ4 (OT attack simulation)
BIO2 (NEN-EN-ISO/IEC 27001/27002)	SQ3 (defense structure), SQ5 (national logging and alerting baselines)
Cyberbeveiligingswet (Cbw / NIS2)	SQ2 (legal incident-response and reporting drivers), SQ4 (containment and reporting validation)

Standard	Applicable Sub Questions
NCSC OT/IACS guidance	SQ1 (OT monitoring methods), SQ2 (OT-safe automated response), SQ3 (IT/OT layering)

6 How Standards Will Be Applied

The standards identified in this document will be applied throughout the project in the following ways:

1. **Literature review phase** : The standards will be reviewed as primary sources alongside academic and industry literature, providing the normative baseline for monitoring requirements.
2. **Infrastructure analysis phase** : Selected controls from NIST SP 800-190, ISO/IEC 27001 Annex A, CIS Controls v8, and the BIO2 will be used as an evaluation checklist to identify gaps in RobotLab’s current monitoring setup.
3. **Design phase** : The reference architecture will be designed to address the applicable controls and align with the ISCM model from SP 800-137 and the IDPS design guidance from SP 800-94, while observing the OT-safe monitoring constraints set out by NIST SP 800-82, IEC 62443, and the NCSC OT/IACS guidance.
4. **Validation phase** : The MITRE ATT&CK framework will be used to map detection coverage, and ISO/IEC 27035 will inform the response workflow validation. CIS Controls v8 will serve as a practical checklist for implementation coverage.
5. **Evaluation phase** : The final evaluation will reflect on how well the implemented solution aligns with the applicable international and Dutch national standards – including the BIO2 baseline and the obligations arising from the Cyberbeveiligingswet – and which gaps remain for future work.

7 Conclusion

This document has identified the key standards and frameworks applicable to the Advanced Threat Monitoring project for RobotLab. The international standards cover the full technical scope of the project, from continuous monitoring strategy (NIST SP 800-137) and intrusion detection design (NIST SP 800-94), through container runtime security (NIST SP 800-190), OT security (NIST SP 800-82 and IEC 62443), and incident response

(ISO/IEC 27035), to practical implementation baselines (CIS Controls v8) and detection coverage mapping (MITRE ATT&CK).

These are complemented by the Dutch national standards and legislation applicable to a project carried out at a publicly funded university of applied sciences: the BIO2 baseline, which expresses the relevant ISO/IEC 27002:2022 logging and monitoring controls within a national risk-management framework; the Cyberbeveiligingswet, which gives legal force to the duty of care and incident reporting obligations that the monitoring architecture is intended to support; and the NCSC guidance on OT/IACS monitoring, which provides a national-context, OT-safe complement to the international OT standards.

By grounding the project in both the international and Dutch national standards, the resulting architecture and implementation will be technically rigorous, comparable to industry practice, aligned with the applicable national legislation, and clearly justified in the context of the research questions defined in the Research Plan.

References

- [1] National Institute of Standards and Technology, *NIST Special Publication 800-137: Information Security Continuous Monitoring (ISCM) for Federal Information Systems and Organizations*, NIST, Gaithersburg, MD, 2011.
- [2] National Institute of Standards and Technology, *NIST Special Publication 800-94: Guide to Intrusion Detection and Prevention Systems (IDPS)*, NIST, Gaithersburg, MD, 2007.
- [3] MITRE Corporation, *MITRE ATT&CK: Adversarial Tactics, Techniques, and Common Knowledge*, <https://attack.mitre.org>, 2024.
- [4] Center for Internet Security, *CIS Controls Version 8*, CIS, East Greenbush, NY, 2021.
- [5] International Organization for Standardization, *ISO/IEC 27035-1:2016 – Information Technology – Security Techniques – Information Security Incident Management – Part 1: Principles of Incident Management*, ISO, Geneva, 2016.
- [6] National Institute of Standards and Technology, *NIST Special Publication 800-190: Application Container Security Guide*, NIST, Gaithersburg, MD, 2017.
- [7] International Organization for Standardization, *ISO/IEC 27001:2022 – Information Security, Cybersecurity and Privacy Protection – Information Security Management Systems – Requirements*, ISO, Geneva, 2022.
- [8] International Electrotechnical Commission, *IEC 62443 Series - Industrial Automation and Control Systems Security*, IEC, Geneva, 2018–2023.
- [9] National Institute of Standards and Technology, *NIST Special Publication 800-82 Rev. 3: Guide to Operational Technology (OT) Security*, NIST, Gaithersburg, MD, 2023.
- [10] Centrum Informatiebeveiliging en Privacybescherming (CIP) / Ministerie van Binnenlandse Zaken en Koninkrijksrelaties, *Baseline Informatiebeveiliging Overheid 2 (BIO2), versie 1.3*, Den Haag, gepubliceerd in de Staatscourant, 5 maart 2026. <https://www.bio-overheid.nl/>
- [11] Rijksoverheid / Nationaal Cyber Security Centrum (NCSC), *Cyberbeveiligingswet (Cbw) – Nederlandse implementatie van de NIS2-richtlijn*, aangenomen door de Tweede Kamer op 15 april 2026; verwachte inwerkingtreding 2026. <https://www.ncsc.nl/cyberbeveiligingswet-nis2>
- [12] Nationaal Cyber Security Centrum (NCSC), *Aan de slag met het beveiligen van OT/IACS*, NCSC, Den Haag. <https://www.ncsc.nl/ot-operational-technology/aan-de-slag-met-het-beveiligen-van-otiacs>

- [13] Nationaal Cyber Security Centrum (NCSC) en Algemene Inlichtingen- en Veiligheidsdienst (AIVD), *Handreiking voor implementatie van detectie-oplossingen*, NCSC, Den Haag, 2015 (niet meer actief onderhouden).