

ATCO Technology Co.

Tel.: (+965) 24743017 / 24567725

Fax: (+965) 24743019 / 24567792

P.O. Box: 2355 Jahra, 01025 - Kuwait

Email: sales@atco-kuwait.com

www.atco-kuwait.com

CR NO . 336218



log no - 1930
شركة أتكو التكنولوجية

تلفون : ٢٤٧٤٣٠١٧ / ٢٤٥٦٧٧٢٥ (+٩٦٥)

فاكس : ٢٤٧٤٣٠١٩ / ٢٤٥٦٧٧٩٢ (+٩٦٥)

ص.ب : ٢٣٥٥ الجھراء ، ٠١٠٢٥ - الكوئط

Email: sales@atco-kuwait.com

www.atco-kuwait.com

س.ت. ٣٣٦٢١٨

SERVICE / INSTALLATION REPORT

No.: 63656

Customer	Alor Hospital	Equipment	UPS.
		Model No.	Pure Volt.
		Serial No.	
Authorized Person		Manufacturer	Pure Volt.
Customer Complaint		Location	Alor Hospital
		Contract / Order No.	
Services / Check Carried out		☐ Installation	☐ Warranty
☐ Inspection / Cleaning	☐ Optics Checks	☐ Repair	☐ On Charge
☐ Calibration / Performance	☐ Pneumatic Checks	☐ Maintenance	☐ Contract
☐ Interface / Communication	☐ Hydraulic Checks	☐ Upgrade	☐ Em
☐ Safety Checks	☐ Operational Error		
☐ Electrical / Electronics	☐ Mechanical Checks		
☐ Accessories Check	☐	Time Spent	
Remarks	Service call attended. Found Inverter module and UPS Batteries are faulty. Need to change the UPS.		
No.	Spare Parts Used	Part No.	Qty.
Service Engineer	Authorized Person	Customer / User	
Signature	Signature	Signature	
Date	Date	Date	