

ATCO Technology Co.

Tel.: (+965) 24743017 / 24567725

Fax: (+965) 24743019 / 24567792

P.O. Box: 2355 Jahra, 01025 - Kuwait

Email: sales@atco-kuwait.com

www.atco-kuwait.com

CR NO . 336218



شركة أتكو التكنولوجية

تلفون : ٢٤٧٤٣٠١٧ / ٢٤٥٦٧٧٢٥ (+٩٦٥)

فاكس : ٢٤٧٤٣٠١٩ / ٢٤٥٦٧٧٩٢ (+٩٦٥)

ص.ب : ٢٣٥٥ الجهره , ٠١٠٢٥ - الكويت

Email: sales@atco-kuwait.com

www.atco-kuwait.com

س.ت. ٣٣٦٢١٨

SERVICE / INSTALLATION REPORT

No.: 60504

Customer	Alors Hospital	Equipment	Voltage Regulator
		Model No.	ST2000W.
		Serial No.	
Authorized Person		Manufacturer	STAC
Customer Complaint		Location	
cooling fan replacement		Contract / Order No.	

Services / Check Carried out

- | | |
|---|---|
| ☐ Inspection / Cleaning | ☐ Optics Checks |
| ☐ Calibration / Performance | ☐ Pneumatic Checks |
| ☐ Interface / Communication | ☐ Hydraulic Checks |
| ☐ Safety Checks | ☐ Operational Error |
| ☐ Electrical / Electronics | ☐ Mechanical Checks |
| ☐ Accessories Check | ☐ _____ |

- | | |
|---|---------------------------------|
| ☐ Installation | ☐ Warranty |
| ☒ Repair | ☐ On Charge |
| ☐ Maintenance | ☐ Contract |
| ☐ Upgrade | ☐ _____ |

Time Spent

Remarks

we replace the cooling fan for two units of voltage regulator. checked and confirmed that the two units are working in good condition.

No.	Spare Parts Used	Part No.	Qty.
1	cooling fan		2

Service Engineer

Mixom
ATCO Technology Co.

Signature

Date 03/07/2024

Authorized Person

Signature

Date

Customer / User

Signature

Date