Government of Kerala Department of Electrical Inspectorate

Office of the Chief Electrical Inspector

Housing Board Buildings, Shanthi Nagar Thiruvananthapuram 695 001

Phone: 0471 2331104, 0471 2331159

Email: cei@ceikerala.gov.in

Web site: www. ceikerala.gov.in

No: B3 - 8273 / 2016 / CEI

भारतीय मानक ब्यूरो IS 15700

An IS 15700: 2005 Certified Department

Thiruvananthapuram Date: 24 /03 / 2017.

From

The Chief Electrical Inspector, Thiruvananthapuram.

To

M/s. Excel Earthings, 7/729 (A), Mannuthy.P.O., Thrissur - 680 651.

Sir.

Subject:

Department of Electrical Inspectorate - Copper bonded steel rods as earth electrodes as per

IS 3043/1987 - regarding.

Reference:

1. Indian Standard 3043/1987 - Code of Practice for earthing.

2. Minutes of Electrical Inspectors' Conference - 2016.

Please refer to the above. The Department of Electrical Inspectorate has no objection to use Steel -Cored Copper rods as earth electrodes by conforming all the provisions of Clause 9.2.2 of IS 3043/1987 Code of practice for earthing.

> Yours faithfully, Chief Electrical Irspector.