

Alpine HVAC — Equipment Identification Guide

Reference guide for identifying equipment types, critical components excluded from Minimum/Core service tiers, and baseline maintenance hours.



A/C

Outdoor split or packaged condensing unit with a top or side fan; refrigerant lines run to an indoor coil.

Critical components (excluded from Minimum/Core):

Compressor, condenser fan motor, condenser coil, evaporator coil, and major control boards/circuit boards.

4 hrs / yr baseline



AHU

Large sheet-metal cabinet moving air through coils, filters, and a blower — usually in a mechanical room with ductwork on both sides.

Critical components (excluded from Minimum/Core):

Supply fan motor, compressor (if DX), heating or cooling coil, major piping system, and major control boards/circuit boards.

6.5 hrs / yr baseline



Air Compressor

Tank-mounted motor and pump storing compressed air; look for a pressure gauge and piping manifold.

Critical components (excluded from Minimum/Core):

Compressor pump/motor, tank, and major control boards/circuit boards.

2.25 hrs / yr baseline



Boiler — Commercial Large

Large floor-standing combustion appliance with burner, heat exchanger, and venting feeding the hot water/steam loop.

Critical components (excluded from Minimum/Core):

Burner assembly, heat exchanger, major gas train components, and major control boards/circuit boards.

8 hrs / yr baseline



Boiler — Commercial Medium

Mid-size floor or wall-mounted boiler with visible gas piping, venting, and circulator pumps nearby.

Critical components (excluded from Minimum/Core):

Burner assembly, heat exchanger, major gas train components, and major control boards/circuit boards.

6 hrs / yr baseline



Boiler — Light Commercial/Residential Small

Compact wall-hung condensing boiler, typically with PVC intake/exhaust venting.

Critical components (excluded from Minimum/Core):

Burner assembly, heat exchanger, circulator pump, and major control boards/circuit boards.

2 hrs / yr baseline



Chiller

Large air-cooled unit with condenser coils/fans, or a water-cooled shell-and-tube vessel, producing chilled water.

Critical components (excluded from Minimum/Core):

Compressor(s), evaporator, condenser, refrigerant circuit, and major control boards/circuit boards.

17 hrs / yr baseline



Cooling Tower — Small/Medium

Rooftop structure with louvered sides, a fan stack on top, and a water basin below.

Critical components (excluded from Minimum/Core):

Fan motor, gearbox/drive assembly, fill media structure, and basin/sump.

4.5 hrs / yr baseline



Cooling Tower — Large

Larger multi-cell version with multiple fan stacks, often induced or forced draft.

Critical components (excluded from Minimum/Core):

Fan motor(s), gearbox/drive assembly, fill media structure, and basin/sump.

7 hrs / yr baseline



Damper

Metal blade inside ductwork with a visible actuator on the exterior that regulates airflow.

Critical components (excluded from Minimum/Core):

Actuator.

0.25 hrs / yr baseline



Dehumidifier

Standalone or ducted unit with a refrigerant coil and drain line that pulls moisture from the air.

Critical components (excluded from Minimum/Core):

Compressor, condenser fan motor, condenser coil, evaporator coil, and major control boards/circuit boards.

2 hrs / yr baseline




Ductless Split

Wall-mounted indoor head connected to an outdoor condensing unit via refrigerant lines — no ductwork.

Critical components (excluded from Minimum/Core):

Compressor, condenser fan motor, condenser coil, evaporator coil, reversing valve, and major control boards/circuit boards.

2.5 hrs / yr baseline



Electric Heater

Resistance heating element in a duct or cabinet — electrical connections only, no combustion venting.

Critical components (excluded from Minimum/Core):

Heating element and control board/contacter assembly.

0.25 hrs / yr baseline



ERV — Light Commercial

Compact box with two crossing air streams through an energy-recovery core, with two duct pairs in/out.

Critical components (excluded from Minimum/Core):

Energy recovery core, supply/exhaust fan motors, and control board.

2 hrs / yr baseline



Exhaust Fan

Small roof-mounted "mushroom cap" or inline duct fan pulling air out of a space.

Critical components (excluded from Minimum/Core):

Fan motor.

1 hrs / yr baseline



Fan

General air-moving propeller or utility fan, wall-mounted or inline.

Critical components (excluded from Minimum/Core):

Fan motor.

1.25 hrs / yr baseline



FCU

Small cabinet unit (ceiling, wall, or floor) with a coil and blower, fed by chilled/hot water piping.

Critical components (excluded from Minimum/Core):

Fan motor and coil.

3 hrs / yr baseline



Furnace

Gas or electric forced-air unit in a mechanical closet with a blower compartment and venting.

Critical components (excluded from Minimum/Core):

Heat exchanger, burner assembly, and blower motor.

1.5 hrs / yr baseline



Glycol Pump

Small circulator pump inline on hydronic piping, moving glycol solution through the loop.

Critical components (excluded from Minimum/Core):

Pump motor.

2 hrs / yr baseline



Heat Pump

Outdoor unit resembling an A/C condenser but reversible, with a reversing valve for heating and cooling.

Critical components (excluded from Minimum/Core):

Compressor, condenser fan motor, condenser coil, evaporator coil, reversing valve, and major control boards/circuit boards.

2.5 hrs / yr baseline



Hot Water Tank

Vertical cylindrical tank, gas or electric, storing domestic hot water.

Critical components (excluded from Minimum/Core):

Tank and heating element/burner.

1 hrs / yr baseline



Humidifier

Small duct-mounted or standalone unit adding moisture via steam, evaporative pad, or spray.

Critical components (excluded from Minimum/Core):

Steam generator/evaporator pad assembly and control board.

2.5 hrs / yr baseline



Make Up Air Unit (MUA)

Larger rooftop or wall unit conditioning 100% outdoor air, often paired with kitchen exhaust.

Critical components (excluded from Minimum/Core):

Supply fan motor, burner/heating element or DX compressor, heating or cooling coil, and major control boards/circuit boards.

5 hrs / yr baseline



Pump — Small/Medium

Inline or base-mounted circulator pump on hydronic piping.

Critical components (excluded from Minimum/Core):

Pump motor.

1 hrs / yr baseline



Pump — Large

Larger base-mounted centrifugal pump with a coupling guard and larger motor.

Critical components (excluded from Minimum/Core):

Pump motor and coupling assembly.

2 hrs / yr baseline



Rooftop Unit (RTU) — Small/Medium

Packaged rooftop unit combining heating, cooling, and ventilation in one cabinet on a roof curb.

Critical components (excluded from Minimum/Core):

Compressor(s), supply fan motor, heating/cooling coil, and major control boards/circuit boards.

3 hrs / yr baseline



Rooftop Unit (RTU) — Large

Larger packaged rooftop unit, often multi-zone with multiple compressor/fan sections.

Critical components (excluded from Minimum/Core):

Compressor(s), supply fan motor, heating/cooling coil, and major control boards/circuit boards.

4.5 hrs / yr baseline



Tube Heater

Suspended radiant heating tube with a burner at one end — common in warehouses and bays.

Critical components (excluded from Minimum/Core):

Burner assembly and heat exchanger tube.

2 hrs / yr baseline



Unit Heater

Wall or ceiling-hung heater with a fan blowing across a coil — common in shops and warehouses.

Critical components (excluded from Minimum/Core):

Fan motor and heat exchanger.

0.5 hrs / yr baseline



Valve

Control valve on piping with an actuator (electric or pneumatic) mounted on top.

Critical components (excluded from Minimum/Core):

Actuator.

0.5 hrs / yr baseline



Vestibule Heater

Small heater mounted near an entryway to offset door heat loss.

Critical components (excluded from Minimum/Core):

Heating element and control board/contactors assembly.

0.5 hrs / yr baseline



Water Filtration

Cartridge or tank-style filtration system on a water line, with a pressure gauge and bypass valves.

Critical components (excluded from Minimum/Core):

Tank/housing assembly.

2 hrs / yr baseline