

Overview

This manual is intended to:


- Provide instructions to create the selected Use case in True Grid Intelligence (TGI).

For more details about Phase Balance Analysis and how it can be analyzed using the Awesense Platform, please refer to the [UC03 - Phase Balance Analysis.pdf](#) document.

TGI Use Case Notes

This document shows the implementation process of the mentioned use case in the TGI visualization interface, along with a description of how to create such a use case on your data.

The Phase Balance Analysis can be found directly in the TGI for a Placement if the Placement has per-phase measured data. The easiest way is to find the Placement via the TGI Explorer in the main menu (select from the main menu - top hamburger icon) and then select the Placement from the map or table. Clicking on a Placement will open a sidebar on the left side with additional information, and at the bottom of this sidebar is the "Phase Balance" section where clicking on "View Report" will display this report.



The first part of the report focuses on general information about Placement. The second part focuses on phase balance, which is covered more in another use case notes document. The third part of TGI's report focuses specifically on the power factor.

Placement Technical Analysis

Placement Overview

Placement type: Permanent
Element ID: 40135
Location: --

Phase A: 40135
Phase B: 40135
Phase C: 40135

label: 13238
name: 13238
normal_operation_s: closed
tatus:
switchable_element: breaker
_type:


Past week ▼ 29 Sep, 2025 12:00 AM - 6 Oct, 2025 1:41 PM

Phase Balance

Total Imbalance


27.3%

Phase Utilization



Phase Balance Analysis - TGI Use Case Notes

[UC03] - Awesense Platform Use Case



The basic interface of the report offers the possibility to change the different time periods. Placement's imbalance data can be analyzed for two basic charts (histograms):

1. The average for an hour of the day.
2. The average for the day of the week.

These two histograms offer a way of correlating the imbalance with a specific day or hour of the day. This can then lead to better identification of imbalances and better correction actions.

General Note

- This description was created for TGI version 3.10.0. For future versions of TGI, the process might be slightly different.
- Access to the different parts of TGI varies depending on the permissions of the user.
- Users on the Sandbox environments currently have read-only permissions, therefore, this use case may be accessible only for viewing, not creation or editing. If you are interested in the latter, please contact Awesense.
- Some of the data for this use case may be available only on Sandbox tiers 2 & 3, but not on tier 1. If you are interested in upgrading your tier access, please contact Awesense.
- For more information please contact tools@awesense.com.