

Grid Alerts and Warnings - TGI Use Case Notes

[UC18] - Awesense Platform Use Case



Overview

This manual is intended to:


- Provide instructions to create the selected use case in True Grid Intelligence (TGI).

For more details about Grid Alerts & Warnings and how they can be analyzed using Awesense Platform, please refer to the [UC18 - Grid Alerts and Warnings.pdf](#) document.

TGI Use Case Notes

This document shows the implementation process of the mentioned use case in the TGI visualization interface, along with a description of how to create such a use case on your data.

Grid Alerts can be found directly in TGI in the main menu (select from the main menu - top hamburger icon).



Basic interface of TGI's Grid Alerts page offers possibilities:

- to filter different alert types and warnings,
- to filter different alert rules,
- adjust the shown time period,
- search specific sensors' alerts,
- manage new alert rules.

Grid Alerts and Warnings - TGI Use Case Notes

[UC18] - Awesense Platform Use Case



The user interface further shows grid alerts and warnings in three sections:

- histogram view,
- table view,
- map view.

Creating new alerts & warnings is possible by clicking on "Manage Rules".

Alert Rules ×

Rule Name
PF

Alert Level Alarm	Sensor Type Raptor	Sensor Serial	Circuit awefice	Element	☐ Permanent placements only
Unit PF	Operator <	Threshold 0.9	Time Interval 1	Time Unit minutes	

An alert will be triggered if average value in provided time interval passes specified threshold.

Cancel Save

High Current ✎ 🗑

Alert Level Alarm	Sensor Type Raptor
----------------------	-----------------------

Current > 500 A on average for 5 minutes

Low PF ✎ 🗑

Alert Level Alarm	Sensor Type Raptor
----------------------	-----------------------

Power Factor < 0.65 PF on average for 1 minute

To display these alerts and warnings, it is necessary to select at least some parameters - see the example in the picture. In the picture, some examples of created alerts & warnings can be seen - High Current, Low PF. Users can edit or delete existing alert rules.

General Note

- This description was created for TGI version 3.10.0. For future versions of TGI, the process might be slightly different.
- Access to the different parts of TGI varies depending on the permissions of the user.
- Users on the Sandbox environments currently have read-only permissions, therefore, this use case may be accessible only for viewing, not creation or editing. If you are interested in the latter, please contact Awesense.
- Some of the data for this use case may be available only on Sandbox tiers 2 & 3, but not on tier 1. If you are interested in upgrading your tier access, please contact Awesense.
- For more information please contact tools@awesense.com.