



# Leeden NOX

The Gas Professionals

## Certificate of Analysis (Bulk)

To: WOODLEIGH WATERWORKS

Date: DD/MM/YYYY

Type of Product	Liquid Oxygen			
Tanker No.	NOXU7271158			
Batch No.	10B 120525			
File NO.	LNOX/OXY/25/2007			
Test Parameters	Specification	Test Method	Analysis Results	Pass/Fail
Oxygen Content	$\geq 99.6 \%$ (w/w)	Ph. Eur.	99.9 % (w/w)	Pass
Dew Point	$< -65 \text{ }^{\circ}\text{C}$	Capacitance based (A1203)	$-50 \text{ }^{\circ}\text{C}$	Fail
Total Hydrocarbon (as Methane)	$< 20.0 \text{ ppm}$ (v/v)	C	12.39 ppm (v/v)	pass

Remarks: -

Certified by

Issued by



*[Signature]*

Name/ Signature *[Signature]*



*[Signature]*

Name/ Signature *[Signature]*

QA-FM-16-02

Leeden National Oxygen Ltd

1 Shipyard Road, Singapore 628128 / Sales Office: 21 Tanjong Kling Road, Singapore 628047

Tel: (+65) 6265 1222 / (+65) 6265 9355 • Fax: (+65) 6265 1706 • Customer Service Hotline: (+65) 6262 2221

Email: [sgsales.gas@leedennox.com](mailto:sgsales.gas@leedennox.com) • Website: [www.leedennox.com](http://www.leedennox.com)