

SYNTHETIC TEST DOCUMENT — LIFE SCIENCES QUALITY ASSURANCE TEST DATASET — STRICTLY FOR DEMONSTRATION & VALIDATION

Bioreactor Temperature Excursion during Batch Incubation

1. GENERAL INCIDENT INFORMATION

Date of Occurrence:	2026-09-14	Discovery Source:	SCADA Automated Alarm System
Manufacturing Site:	Building 4, Lexington Biopharma Facility	Department / Area:	Bioprocess Manufacturing
Related Product / Material:	Monoclonal Antibody Intermediate mAb-402	Batch / Lot Number:	B-1024

2. EVENT SUMMARY & DEVIATION DESCRIPTION

During standard cell culture growth phase at 03:15, Bioreactor BIO-400 temperature drifted from setpoint 37.0 °C up to 39.4 °C for approximately 42 minutes before cooling loop recalibration stabilized the vessel back to 37.0 °C. Validated allowable excursion limit is ±0.5 °C for maximum 15 minutes.

3. IMMEDIATE ACTIONS & CONTAINMENT MEASURES

Operations team immediately engaged auxiliary chilled glycol loop to bring temperature to 37.0 °C. Batch B-1024 was placed on physical and electronic quality quarantine pending cell viability and glycosylation profile testing.

4. INITIAL LOGGING VERIFICATION

Logged By: Operations Shift Lead Date: 2026-09-14	QA Reviewer: Quality Assurance On-Duty Date: 2026-09-14	Workflow Stage: Awaiting AI Extraction & Human Review
--	--	---