

SYNTHETIC TEST DOCUMENT — LIFE SCIENCES QUALITY ASSURANCE TEST DATASET — STRICTLY FOR DEMONSTRATION & VALIDATION

Cold Storage Unit 2-8 °C Excursion in Primary Quarantine Vault

1. GENERAL INCIDENT INFORMATION

Date of Occurrence:	2026-09-22	Discovery Source:	Building Management System (BMS) Alert
Manufacturing Site:	Cold Chain Logistics Depot, Amsterdam Warehouse	Department / Area:	Supply Chain & Materials Management
Related Product / Material:	Recombinant Insulin Bulk Drug Substance	Batch / Lot Number:	INS-B09

2. EVENT SUMMARY & DEVIATION DESCRIPTION

Walk-in cold room CR-02 temperature rose to 11.2 °C for 3 hours and 25 minutes due to compressor defrost cycle relay failure. Storage specification for recombinant insulin bulk substance is strictly 2.0 °C to 8.0 °C.

3. IMMEDIATE ACTIONS & CONTAINMENT MEASURES

Materials were immediately transferred to backup cold room CR-03. Continuous data logger temperature traces were downloaded for stability evaluation.

4. INITIAL LOGGING VERIFICATION

Logged By: Operations Shift Lead Date: 2026-09-22	QA Reviewer: Quality Assurance On-Duty Date: 2026-09-22	Workflow Stage: Awaiting AI Extraction & Human Review
--	--	---