

SYNTHETIC TEST DOCUMENT — LIFE SCIENCES QUALITY ASSURANCE TEST DATASET — STRICTLY FOR DEMONSTRATION & VALIDATION

# Emergency Generator Transfer Delay during Lyophilization Primary Drying Phase

## 1. GENERAL INCIDENT INFORMATION

|                             |                                          |                     |                                                |
|-----------------------------|------------------------------------------|---------------------|------------------------------------------------|
| Date of Occurrence:         | 2026-09-25                               | Discovery Source:   | Central Facility SCADA Power Monitoring System |
| Manufacturing Site:         | Lyophilization Facility, Boulder Complex | Department / Area:  | Sterile Freeze-Drying Operations               |
| Related Product / Material: | Lyophilized Vaccine Antigen VAX-09       | Batch / Lot Number: | VAX-LOT-7703                                   |

## 2. EVENT SUMMARY & DEVIATION DESCRIPTION

Municipal electrical grid disturbance caused facility power drop. Uninterruptible Power Supply (UPS) engaged, but automatic transfer switch to diesel generator delayed by 4 minutes and 30 seconds. Chamber vacuum degraded from 0.08 mbar to 0.42 mbar during primary drying.

## 3. IMMEDIATE ACTIONS & CONTAINMENT MEASURES

Vacuum pumps were manually re-engaged upon generator start. Lyophilizer condenser and shelf temperature curves were logged. Batch VAX-LOT-7703 was segregated for moisture and reconstitution analytics.

## 4. INITIAL LOGGING VERIFICATION

|                                                      |                                                            |                                                       |
|------------------------------------------------------|------------------------------------------------------------|-------------------------------------------------------|
| Logged By: Operations Shift Lead<br>Date: 2026-09-25 | QA Reviewer: Quality Assurance On-Duty<br>Date: 2026-09-25 | Workflow Stage: Awaiting AI Extraction & Human Review |
|------------------------------------------------------|------------------------------------------------------------|-------------------------------------------------------|