

Group	Q1: Simple Rankine	Q2: Reheat Rankine	Q3: Reheat-Regenerative	Q4: Regenerative (2 FWH)	Q5: Combined Cycle
G1	P_high = 2 MPa T_high = 400°C P_low = 50 kPa	W_net = 80 MW P_1 = 10 MPa T_1 = 500°C P_3 = 1 MPa T_3 = 500°C P_cond = 10 kPa	W_net = 80 MW P_1 = 10 MPa T_1 = 550°C P_extract = 0.8 MPa T_reheat = 500°C P_cond = 10 kPa	W_net = 400 MW P_1 = 10 MPa T_1 = 600°C P_closed = 1.2 MPa P_open = 0.6 MPa P_cond = 10 kPa	r_p = 6 T_air_in = 300 K m_air = 14 kg/s T_IT_gas = 1500 K T_steam_in = 400°C P_steam = 10 MPa P_cond_steam = 15 kPa T_gas_out = 420 K
G2	P_high = 3 MPa T_high = 450°C P_low = 20 kPa	W_net = 90 MW P_1 = 12 MPa T_1 = 520°C P_3 = 1.2 MPa T_3 = 520°C P_cond = 12 kPa	W_net = 90 MW P_1 = 12 MPa T_1 = 560°C P_extract = 1.0 MPa T_reheat = 520°C P_cond = 12 kPa	W_net = 350 MW P_1 = 12 MPa T_1 = 580°C P_closed = 1.5 MPa P_open = 0.8 MPa P_cond = 12 kPa	r_p = 7 T_air_in = 295 K m_air = 15 kg/s T_IT_gas = 1520 K T_steam_in = 420°C P_steam = 12 MPa P_cond_steam = 12 kPa T_gas_out = 410 K
G3	P_high = 4 MPa T_high = 500°C P_low = 15 kPa	W_net = 100 MW P_1 = 14 MPa T_1 = 540°C P_3 = 1.4 MPa T_3 = 540°C P_cond = 8 kPa	W_net = 100 MW P_1 = 14 MPa T_1 = 580°C P_extract = 1.2 MPa T_reheat = 540°C P_cond = 8 kPa	W_net = 450 MW P_1 = 14 MPa T_1 = 620°C P_closed = 1.8 MPa P_open = 1.0 MPa P_cond = 8 kPa	r_p = 8 T_air_in = 290 K m_air = 16 kg/s T_IT_gas = 1550 K T_steam_in = 440°C P_steam = 14 MPa P_cond_steam = 10 kPa T_gas_out = 400 K

Group	Q1: Simple Rankine	Q2: Reheat Rankine	Q3: Reheat-Regenerative	Q4: Regenerative (2 FWH)	Q5: Combined Cycle
G4	P_high = 5 MPa T_high = 420°C P_low = 25 kPa	W_net = 110 MW P_1 = 16 MPa T_1 = 480°C P_3 = 1.6 MPa T_3 = 480°C P_cond = 15 kPa	W_net = 110 MW P_1 = 16 MPa T_1 = 520°C P_extract = 1.4 MPa T_reheat = 480°C P_cond = 15 kPa	W_net = 500 MW P_1 = 16 MPa T_1 = 560°C P_closed = 2.0 MPa P_open = 1.2 MPa P_cond = 15 kPa	r_p = 9 T_air_in = 305 K m_air = 17 kg/s T_IT_gas = 1480 K T_steam_in = 380°C P_steam = 16 MPa P_cond_steam = 20 kPa T_gas_out = 430 K
G5	P_high = 6 MPa T_high = 480°C P_low = 30 kPa	W_net = 120 MW P_1 = 18 MPa T_1 = 560°C P_3 = 1.8 MPa T_3 = 560°C P_cond = 20 kPa	W_net = 120 MW P_1 = 18 MPa T_1 = 600°C P_extract = 1.6 MPa T_reheat = 560°C P_cond = 20 kPa	W_net = 550 MW P_1 = 18 MPa T_1 = 640°C P_closed = 2.2 MPa P_open = 1.4 MPa P_cond = 20 kPa	r_p = 10 T_air_in = 310 K m_air = 18 kg/s T_IT_gas = 1600 K T_steam_in = 460°C P_steam = 18 MPa P_cond_steam = 25 kPa T_gas_out = 440 K
G6	P_high = 7 MPa T_high = 520°C P_low = 35 kPa	W_net = 130 MW P_1 = 20 MPa T_1 = 580°C P_3 = 2.0 MPa T_3 = 580°C P_cond = 25 kPa	W_net = 130 MW P_1 = 20 MPa T_1 = 620°C P_extract = 1.8 MPa T_reheat = 580°C P_cond = 25 kPa	W_net = 600 MW P_1 = 20 MPa T_1 = 660°C P_closed = 2.4 MPa P_open = 1.6 MPa P_cond = 25 kPa	r_p = 11 T_air_in = 315 K m_air = 19 kg/s T_IT_gas = 1620 K T_steam_in = 480°C P_steam = 20 MPa P_cond_steam = 30 kPa T_gas_out = 450 K

Group	Q1: Simple Rankine	Q2: Reheat Rankine	Q3: Reheat-Regenerative	Q4: Regenerative (2 FWH)	Q5: Combined Cycle
G7	P_high = 8 MPa T_high = 380°C P_low = 40 kPa	W_net = 70 MW P_1 = 8 MPa T_1 = 460°C P_3 = 0.8 MPa T_3 = 460°C P_cond = 30 kPa	W_net = 70 MW P_1 = 8 MPa T_1 = 500°C P_extract = 0.6 MPa T_reheat = 460°C P_cond = 30 kPa	W_net = 300 MW P_1 = 8 MPa T_1 = 540°C P_closed = 1.0 MPa P_open = 0.4 MPa P_cond = 30 kPa	r_p = 12 T_air_in = 320 K m_air = 20 kg/s T_IT_gas = 1580 K T_steam_in = 360°C P_steam = 8 MPa P_cond_steam = 35 kPa T_gas_out = 460 K
G8	P_high = 9 MPa T_high = 550°C P_low = 45 kPa	W_net = 140 MW P_1 = 22 MPa T_1 = 600°C P_3 = 2.2 MPa T_3 = 600°C P_cond = 35 kPa	W_net = 140 MW P_1 = 22 MPa T_1 = 640°C P_extract = 2.0 MPa T_reheat = 600°C P_cond = 35 kPa	W_net = 650 MW P_1 = 22 MPa T_1 = 680°C P_closed = 2.6 MPa P_open = 1.8 MPa P_cond = 35 kPa	r_p = 13 T_air_in = 325 K m_air = 21 kg/s T_IT_gas = 1650 K T_steam_in = 500°C P_steam = 22 MPa P_cond_steam = 40 kPa T_gas_out = 470 K
G9	P_high = 10 MPa T_high = 580°C P_low = 10 kPa	W_net = 150 MW P_1 = 24 MPa T_1 = 620°C P_3 = 2.4 MPa T_3 = 620°C P_cond = 5 kPa	W_net = 150 MW P_1 = 24 MPa T_1 = 660°C P_extract = 2.2 MPa T_reheat = 620°C P_cond = 5 kPa	W_net = 700 MW P_1 = 24 MPa T_1 = 700°C P_closed = 2.8 MPa P_open = 2.0 MPa P_cond = 5 kPa	r_p = 14 T_air_in = 330 K m_air = 22 kg/s T_IT_gas = 1680 K T_steam_in = 520°C P_steam = 24 MPa P_cond_steam = 5 kPa T_gas_out = 480 K

Group	Q1: Simple Rankine	Q2: Reheat Rankine	Q3: Reheat-Regenerative	Q4: Regenerative (2 FWH)	Q5: Combined Cycle
G10	$P_{\text{high}} = 1.5 \text{ MPa}$ $T_{\text{high}} = 350^{\circ}\text{C}$ $P_{\text{low}} = 5 \text{ kPa}$	$W_{\text{net}} = 60 \text{ MW}$ $P_1 = 6 \text{ MPa}$ $T_1 = 440^{\circ}\text{C}$ $P_3 = 0.6 \text{ MPa}$ $T_3 = 440^{\circ}\text{C}$ $P_{\text{cond}} = 5 \text{ kPa}$	$W_{\text{net}} = 60 \text{ MW}$ $P_1 = 6 \text{ MPa}$ $T_1 = 480^{\circ}\text{C}$ $P_{\text{extract}} = 0.4 \text{ MPa}$ $T_{\text{reheat}} = 440^{\circ}\text{C}$ $P_{\text{cond}} = 5 \text{ kPa}$	$W_{\text{net}} = 250 \text{ MW}$ $P_1 = 6 \text{ MPa}$ $T_1 = 520^{\circ}\text{C}$ $P_{\text{closed}} = 0.8 \text{ MPa}$ $P_{\text{open}} = 0.2 \text{ MPa}$ $P_{\text{cond}} = 5 \text{ kPa}$	$r_p = 5$ $T_{\text{air_in}} = 285 \text{ K}$ $m_{\text{air}} = 13 \text{ kg/s}$ $T_{\text{IT_gas}} = 1450 \text{ K}$ $T_{\text{steam_in}} = 350^{\circ}\text{C}$ $P_{\text{steam}} = 6 \text{ MPa}$ $P_{\text{cond_steam}} = 5 \text{ kPa}$ $T_{\text{gas_out}} = 380 \text{ K}$