

ഭരണഭാഷ-മാതൃഭാഷ



## മാനന്തവാടി മുനിസിപ്പാലിറ്റി

പിൻ കോഡ്: 670645 ജി എസ് ടി: 32AAAALS4604A1ZO

ഫോൺ നമ്പർ: 04935-240253 ഇമെയിൽ: mndymunicipality@gmail.com

<https://mananthavadmunicipality.lsgkerala.gov.in>,

സർട്ടിഫിക്കറ്റ് നമ്പർ : 1488769-2024

തീയതി : 05-07-2024

### SANITARY CERTIFICATE

Sub: Mananthavady Municipality - Health Department - granting Sanitation Certificate - Reg.

Ref: (1) Application of the Sanjoe Public School, dated 6/6/202

(2) Health Inspector's report dated 28/6/2024

This is to certify that SANJOE PUBLIC SCHOOL, situated in Building Nos. XXIX/347 has been inspected as per Ref. No (1) and found that the sanitary conditions of above premises are satisfactory.

Document certified by SANTHOSH KUMAR P S  
<santhoshsroedhar@gmail.com>

Digitally signed by SANTHOSH KUMAR P S  
Date: 2024.07.05 14:30:50 IST  
Reason: KSMART

ക്ലീൻ സിറ്റി മാനേജർ

Manager  
Sanjoe Public School  
Kaniyaram, Manantavady

Principal  
Sanjoe Public School  
Kaniyaram, Manantavady



## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Sajesh N.K., Health Inspector

(Name of Officers with designation) from P. H.C Kurukanmoola.PHED

inspected the Sanjoe Public School Kaniyaram

(Name & Address of the school) on 08-07-2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. QUA\_135683 dated 27/05/24

of Quality Control Sub Dist. Lab Mdy PHED Lab) certified that the

Sanjoe Public school (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 27-05-2025

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

Sajesh N.K.  
Health Inspector  
PHC Kurukanmoola  
HEALTH INSPECTOR  
PRIMARY HEALTH CENTRE  
KURUKANMOOLA  
Manantavady

To The Principal  
Sanjoe Public School Kaniyaram  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

[Signature]  
**Manager**  
**Sanjoe Public School**  
**Kaniyaram, Manantavady**



[Signature]  
**Principal**  
**Sanjoe Public School**  
**Kaniyaram, Manantavady**





# KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB

MANANTHAVADY, WAYANAD

PHONE: 04935-294131

Email: qcsdlmananthavadi@gmail.com

## TEST REPORT

ULR No-TC1059324000000741F

Report No -KWA/MNDY/741/2024 (QUA\_135583)

Date: 27/05/2024

Customer Name & Address	1.Date of Receipt	:24/05/2024
Sanjoe Public School Kaniyaram Mananthavady	2.Sampling done by	:Health Inspector
	3.Sample code	: 741/2024
	4.Nature of sample	:Drinking Water from Bore Well Water
	5.Sample quantity	: 1 LTR
	6.Test performing dates	From: 24/05/2024 To: 27/05/2024

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Colour	Pt Co. unit	IS 3025 (part 4)-2021(Platinum Cobalt-Visual Comparison)	5	1
2	Odour		IS 3025 (part 5)-2018	Agreeable	Agreeable
3	Taste		IS 3025(part 8)- 1984	Agreeable	Agreeable
4	Turbidity	(NTU)	IS 3025 (part 10)-1984(Nelphometric method)	1	0.11
5	pH at --- °C		IS 3025 (PART 11)-2022(Electrometric Method)	6.5 to 8.5	6.82
6	Alkalinity	(mg/litre)	IS 3025 (PART 23)-2023(Indicator Method)	200	15.84
7	Total Dissolved Solids (TDS)	(mg/litre)	IS 3025 (part 16)-2023(Gravimetric method)	500	62
8	Total Hardness (as CaCO <sub>3</sub> )	(mg/litre)	IS 3025 (part 21)-2009(EDTA Method)	200	37.26
9	Calcium (as Ca)	(mg/litre)	IS 3025 (part 40)-1994(EDTA Method)	75	3.93
10	Magnesium (as Mg)	(mg/litre)	IS 3025 (part 46)-1994 (Volumetric Method Using EDTA)	30	6.80
11	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32)-1988 (Argentometric Mthod)	250	13.59

NB:- The results stated above related only to the samples(S) submitting for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.

Analyzed By: Technical Manager

Authorized By: Deputy Quality Manager

DEPUTY QUALITY MANAGER

Quality Control Sub District Laboratory

Mananthavady, Wayanad

KWA/QCSDL/MNDY/F/04 Issue No. 01

\*End of Report\*  
Issue Date: 01/10/2021 Rev.No. 00



Manager  
Sanjoe Public School  
Kaniyaram, Mananthavady

Principal  
Sanjoe Public School  
Kaniyaram, Mananthavady





# KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB

MANANTHAVADY, WAYANAD

PHONE: 04935-294131

Email: qcsdlmananthavadi@gmail.com

## TEST REPORT

Report No -KWA/MNDY/741/2024 (QUA\_135583)

Date: 27/05/2024

Customer Name & Address  Sanjoe Public School Kaniyaram Mananthavady	1.Date of Receipt	:24/05/2024
	2.Sampling done by	:Health Inspector
	3.Sample code	: 741/2024
	4.Nature of sample	:Drinking Water from Bore Well Water
	5.Sample quantity	: 1 LTR
	6.Test performing dates From: 24/05/2024	To: 27/05/2024

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
12	Electrical conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14)-2013 (Wheatstone Bridge Conductance Cell Method)		103.8
13	Acidity	(mg/litre)	IS 3025 (part 22)-1986(Indicator Method)		0
14	Sulphate (as SO <sub>4</sub> )	(mg/litre)	IS 3025 (PART 24)-1986 (Turbidity Method)	200	1.56
15	Phosphate [as PO <sub>4</sub> ]	(mg/litre)	IS 3025 (PART 31)-2008 (Spectrophotometric method)		--
16	Fluoride (as F)	(mg/litre)	IS 3025 (part 60)-2008 (Spectrophotometric method)	1.0	--
17	Iron (as Fe)	(mg/litre)	IS 3025 (part 53)-2003 (Spectrophotometric method)	1.0	0.1
18	Nitrate (as NO <sub>3</sub> )	(mg/litre)	IS 3025 (part 34)-1988 (Spectrophotometric method)	45	10.6
19	Ammonia	(mg/litre)	IS 3025 (part 34)-2008 (UV method)	0.5	--
20	Residual Chlorine	(mg/litre)	IS 3025 (part 26)-1986 (Stablised Neutral O-Toludine Method)	0.2	--

NB:- The results stated above related only to the samples(S) submitting for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.

Analyzed By: Technical Manager

Authorized By: Deputy Quality Manager  
DEPUTY QUALITY MANAGER  
Quality Control Sub District Laboratory  
Mananthavady, Wayanad

KWA/QCSDL/MNDY/F/04 Issue No. 01



Issue Date: 20/10/2021 Rev.No. 00

Rev.Date : 00

Principal  
Sanjoe Public School  
Kaniyaram, Mananthavady

Principal  
Sanjoe Public School  
Kaniyaram, Mananthavady





# KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB

MANANTHAVADY, WAYANAD

PHONE: 04935-294131

Email: qcsdlmananthavadi@gmail.com

## TEST REPORT

Report No -KWA/MNDY/741/2024 (QUA\_135583)

Date: 27/05/2024

Customer Name & Address  Sanjoe Public School Kaniyaram Mananthavady	1.Date of Receipt	:24/05/2024
	2.Sampling done by	:Health Inspector
	3.Sample code	: 741/2024
	4.Nature of sample	:Drinking Water from Bore Well Water
	5.Sample quantity	: 1 LTR
	6.Test performing dates	From: 24/05/2024 To: 27/05/2024

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Coliforms	CFU/100 ml	IS 15185(part1) 2002 reaffirmed2016	Shall not be detectable in any 100ml sample	NIL
2	E coli	CFU/100 ml	IS 15185(part1) 2002 reaffirmed2016	Shall not be detectable in any 100ml sample	NIL

NB: - The results stated above related only to the samples(S) submitting for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.


Tested by:

Authorized By: Micro Biologist

  
**Manager**  
Sanjoe Public School  
Kaniyaram, Mananthavady

\*End of Report\*



  
**Principal**  
Sanjoe Public School  
Kaniyaram, Mananthavady