

# EcoPulse | Healthcare Sustainability Report

National Healthcare Environmental Decarbonization Framework

GRADE A+

September 2024

## Fortis Hospitals Bengaluru

Reg No: HOS-KA-2024-003 | NABH: Accredited | Type: Corporate

Location: Bengaluru, Karnataka | Bed Capacity: 300 Beds

### SUSTAINABILITY INDEX

79.9 / 100

Performance: Optimal

## 1. Carbon Footprint Assessment (tCO2e)

| Emission Category                       | Activity Source             | Emissions (tCO2e) | % Contribution |
|-----------------------------------------|-----------------------------|-------------------|----------------|
| Scope 1 - Diesel Generators             | Backup Generation           | 2.0948            | 6.0%           |
| Scope 1 - Medical Gases                 | N2O & Anaesthetic Gases     | 0.2740            | 0.8%           |
| Scope 1 - Transport Fleet               | Hospital Ambulances / Fleet | 0.4534            | 1.3%           |
| Scope 2 - Grid Electricity              | State Utility Grid Supply   | 31.4891           | 90.5%          |
| TOTAL NET EMISSIONS (Scope 1 + Scope 2) |                             | 34.7913 tCO2e     | 100.0%         |

\* Specific Carbon Intensity: 0.1160 tCO2e / bed / month (Benchmark: < 0.20 tCO2e/bed)

## 2. Resource Consumption & Utilities

### Electricity & Solar

Total Units: 56,874 kWh  
Grid Share: 68%  
Renewable: 32%  
Bill Amount: INR 494,235

### Water Management

Municipal Draw: 201 kL  
Borewell / Tanker: 111 kL  
Total Water: 312.0 kL  
STP Recycled: 0 kL

### Biomedical & Waste

Biomedical Total: 939.0 kg  
Yellow / Red: 678.0 kg  
General Waste: 750.0 kg  
Recycled: 105.0 kg

## 3. Targeted Sustainability Recommendations

HIGH

DIESEL

Generator runtime exceeds 40 hrs/month. Review DG scheduling and perform preventive m

MEDIUM

GASES

Nitrous oxide consumption is elevated. Audit anaesthetic gas lines for leaks and wast