

Bit	Code	Feature	Summary
0	TEMP	TemperatureUnit	The Node can be configured to use different units of temperature when conveying values to a user.

11.5.5. Data Types

11.5.5.1. TempUnitEnum Type

This data type is derived from [enum8](#).

Value	Name	Summary	Conformance
0	Fahrenheit	Temperature conveyed in Fahrenheit	O.a2+
1	Celsius	Temperature conveyed in Celsius	O.a2+
2	Kelvin	Temperature conveyed in Kelvin	O.a2+

11.5.6. Attributes

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0x0000	TemperatureUnit	TempUnitEnum	all	N		RW VM	TEMP
0x0001	SupportedTemperatureUnits	list[TempUnitEnum]	2 to 3	F		R V	TEMP

11.5.6.1. TemperatureUnit Attribute

This attribute SHALL indicate the unit for the Node to use only when conveying temperature in communication to the user, for example such as via a user interface on the device. If provided, this value SHALL take priority over any unit implied through the [ActiveLocale Attribute](#).

An attempt to write to this attribute with a value not included in the SupportedTemperatureUnits attribute list SHALL result in a CONSTRAINT_ERROR.

11.5.6.2. SupportedTemperatureUnits Attribute

This attribute SHALL indicate a list of units supported by the Node to be used when writing the TemperatureUnit attribute of this cluster. Each entry in the list SHALL be unique.