

### 2.2.5.5. LightSensorType Attribute

This attribute SHALL indicate the electronic type of the light sensor. This attribute SHALL be set to one of the non-reserved values listed in [LightSensorTypeEnum](#) or null in case the sensor type is unknown.

## 2.3. Temperature Measurement Cluster

This cluster provides an interface to temperature measurement functionality, including configuration and provision of notifications of temperature measurements.

### 2.3.1. Revision History

The global ClusterRevision attribute value SHALL be the highest revision number in the table below.

| Revision | Description                                      |
|----------|--------------------------------------------------|
| 1        | Mandatory global ClusterRevision attribute added |
| 2        | CCB 2241 2370                                    |
| 3        | CCB 2823                                         |
| 4        | New data model format and notation               |

### 2.3.2. Classification

| Hierarchy | Role        | Scope    | PICS Code |
|-----------|-------------|----------|-----------|
| Base      | Application | Endpoint | TMP       |

### 2.3.3. Cluster ID

| ID     | Name                    |
|--------|-------------------------|
| 0x0402 | Temperature Measurement |

### 2.3.4. Attributes

| ID     | Name                  | Type        | Constraint                           | Quality | Fallback | Access | Conformance |
|--------|-----------------------|-------------|--------------------------------------|---------|----------|--------|-------------|
| 0x0000 | <b>Measured-Value</b> | temperature | MinMeasuredValue to MaxMeasuredValue | P X     |          | R V    | M           |