

2.11.5.1.1. Normal Value

This value SHALL indicate that this alarm is not alarming.

2.11.5.1.2. Warning Value

This value SHALL indicate that this alarm is in a warning state. Alarms in this state SHOULD be subject to being muted via physical interaction.

2.11.5.1.3. Critical Value

This value SHALL indicate that this alarm is in a critical state. Alarms in this state SHALL NOT be subject to being muted via physical interaction.

2.11.5.2. SensitivityEnum Type

This data type is derived from enum8.

Value	Name	Summary	Conformance
0	High	High sensitivity	O
1	Standard	Standard Sensitivity	M
2	Low	Low sensitivity	O

2.11.5.3. ExpressedStateEnum Type

This data type is derived from enum8.

Value	Name	Summary	Conformance
0	Normal	Nominal state, the device is not alarming	M
1	SmokeAlarm	Smoke Alarm state	SMOKE
2	COAlarm	CO Alarm state	CO
3	BatteryAlert	Battery Alert State	M
4	Testing	Test in Progress	M
5	HardwareFault	Hardware Fault Alert State	M
6	EndOfService	End of Service Alert State	M
7	InterconnectSmoke	Interconnected Smoke Alarm State	O
8	InterconnectCO	Interconnected CO Alarm State	O