

The reporting interval of this attribute SHALL be manufacturer dependent. The server MAY choose to omit publication of deltas considered not meaningful.

The server SHALL NOT mark this attribute ready for report if the last time this was done was more recently than 1 second ago.

The server MAY delay marking this attribute ready for report for longer periods if needed, however the server SHALL NOT delay marking this attribute as ready for report for longer than 60 seconds.

If the cumulative energy imported cannot currently be determined, a value of null SHALL be returned.

2.12.6.3. CumulativeEnergyExported Attribute

This attribute SHALL indicate the most recent measurement of cumulative energy exported by the server over the lifetime of the device, and the timestamp of when the measurement was recorded.

The reporting interval of this attribute SHALL be manufacturer dependent. The server MAY choose to omit publication of deltas considered not meaningful.

The server SHALL NOT mark this attribute ready for report if the last time this was done was more recently than 1 second ago.

The server MAY delay marking this attribute ready for report for longer periods if needed, however the server SHALL NOT delay marking this attribute as ready for report for longer than 60 seconds.

If the cumulative energy exported cannot currently be determined, a value of null SHALL be returned.

2.12.6.4. PeriodicEnergyImported Attribute

This attribute SHALL indicate the most recent measurement of energy imported by the server and the period during which it was measured.

The reporting interval of this attribute SHALL be manufacturer dependent. The server MAY choose to omit publication of deltas considered not meaningful.

The server SHALL NOT mark this attribute ready for report if the last time this was done was more recently than 1 second ago.

The server MAY delay marking this attribute ready for report for longer periods if needed, however the server SHALL NOT delay marking this attribute as ready for report for longer than 60 seconds.

If the periodic energy imported cannot currently be determined, a value of null SHALL be returned.

2.12.6.5. PeriodicEnergyExported Attribute

This attribute SHALL indicate the most recent measurement of energy exported by the server and the period during which it was measured.

The reporting interval of this attribute SHALL be manufacturer dependent. The server MAY choose