

The reporting interval of this attribute SHALL be manufacturer dependent. The server MAY choose to omit publication of deltas considered not meaningful.

The server SHALL NOT mark this attribute ready for report if the last time this was done was more recently than 1 second ago.

The server MAY delay marking this attribute ready for report for longer periods if needed, however the server SHALL NOT delay marking this attribute as ready for report for longer than 60 seconds.

If the active or reactive currents cannot be measured, a value of null SHALL be returned.

2.13.6.9. ActivePower Attribute

This SHALL indicate the most recent [ActivePower](#) reading in milliwatts (mW). If the power cannot be measured, a value of null SHALL be returned.

A positive value represents power imported, while a negative value represents power exported.

The reporting interval of this attribute SHALL be manufacturer dependent. The server MAY choose to omit publication of deltas considered not meaningful.

The server SHALL NOT mark this attribute ready for report if the last time this was done was more recently than 1 second ago.

The server MAY delay marking this attribute ready for report for longer periods if needed, however the server SHALL NOT delay marking this attribute as ready for report for longer than 60 seconds.

If the [Polyphase Power](#) feature is set, this value represents the combined active power imported or exported.

2.13.6.10. ReactivePower Attribute

This SHALL indicate the most recent [ReactivePower](#) reading in millivolt-amps reactive (mVAR).

A positive value represents power imported, while a negative value represents power exported.

The reporting interval of this attribute SHALL be manufacturer dependent. The server MAY choose to omit publication of deltas considered not meaningful.

The server SHALL NOT mark this attribute ready for report if the last time this was done was more recently than 1 second ago.

The server MAY delay marking this attribute ready for report for longer periods if needed, however the server SHALL NOT delay marking this attribute as ready for report for longer than 60 seconds.

If the reactive power cannot be measured, a value of null SHALL be returned.

If the [Polyphase Power](#) feature is supported, this value represents the combined reactive power imported or exported.