

Bit	Code	Feature	Conformance	Summary
0	PRSCONST	ConstantPressure	O.a+	Supports operating in constant pressure mode
1	PRSCOMP	CompensatedPressure	O.a+	Supports operating in compensated pressure mode
2	FLW	ConstantFlow	O.a+	Supports operating in constant flow mode
3	SPD	ConstantSpeed	O.a+	Supports operating in constant speed mode
4	TEMP	ConstantTemperature	O.a+	Supports operating in constant temperature mode
5	AUTO	Automatic	O	Supports operating in automatic mode
6	LOCAL	LocalOperation	O	Supports operating using local settings

4.2.5. Dependencies

Where external pressure, flow, and temperature measurements are processed by this cluster (see [ControlMode Attribute](#)), these are provided by a Pressure Measurement cluster, a Flow Measurement cluster, and a Temperature Measurement client cluster, respectively. These 3 client clusters are used for connection to a remote sensor device. The pump is able to use the sensor measurement provided by a remote sensor for regulation of the pump speed.

Note that control of the pump setpoint is not included in this cluster – the On/Off and Level Control clusters (see [Typical Usage of Pump Configuration and Control Cluster](#)) MAY be used by a pump device to turn it on and off and control its setpoint. Note that the Pump Configuration and Control cluster MAY override on/off/setpoint settings for specific operation modes (see [OperationMode Attribute](#) for detailed description of the operation and control of the pump.).

4.2.6. Data Types

4.2.6.1. PumpStatusBitmap Type

This data type is derived from map16.