

Bit	Name	Summary	Conformance
0	DeviceFault	A fault related to the system or pump device is detected.	M
1	SupplyFault	A fault related to the supply to the pump is detected.	M
2	SpeedLow	Setpoint is too low to achieve.	M
3	SpeedHigh	Setpoint is too high to achieve.	M
4	LocalOverride	Device control is overridden by hardware, such as an external STOP button or via a local HMI.	M
5	Running	Pump is currently running	M
6	RemotePressure	A remote pressure sensor is used as the sensor for the regulation of the pump.	M
7	RemoteFlow	A remote flow sensor is used as the sensor for the regulation of the pump.	M
8	RemoteTemperature	A remote temperature sensor is used as the sensor for the regulation of the pump.	M

4.2.6.1.1. DeviceFault Bit

If this bit is set, it MAY correspond to an event in the range 2-16, see [Events](#).

4.2.6.1.2. SupplyFault Bit

If this bit is set, it MAY correspond to an event in the range 0-1 or 13, see [Events](#).

4.2.6.1.3. LocalOverride Bit

While this bit is set, the EffectiveOperationMode is adjusted to Local. Any request changing OperationMode SHALL generate a FAILURE error status until LocalOverride is cleared on the physical device. When LocalOverride is cleared, the device SHALL return to the operation mode set in OperationMode.