

Revision	Description
5	New data model format and notation, added FeatureMap, collapsed attribute sets, clarified edge cases around limits, default value of xxxSetpointLimit now respects AbsxxxSetpointLimit
6	Introduced the LTNE feature and adapted text (spec issue #5778)
7	Update constraints on local temperature calibration and minimum setpoint deadband and introduced Presets and MatterScheduleConfiguration features
8	Added comment regarding writing to ControlSequenceOfOperation.
9	Removed AlarmMask attribute and AlarmCodeBitmap Type.

4.3.2. Classification

Hierarchy	Role	Scope	PICS Code
Base	Application	Endpoint	TSTAT

4.3.3. Cluster ID

ID	Name
0x0201	Thermostat

4.3.4. Features

This cluster SHALL support the FeatureMap bitmap attribute as defined below.

Bit	Code	Feature	Conformance	Summary
0	HEAT	Heating	AUTO, O.a+	Thermostat is capable of managing a heating device
1	COOL	Cooling	AUTO, O.a+	Thermostat is capable of managing a cooling device
2	OCC	Occupancy	O	Supports Occupied and Unoccupied setpoints