

Bit	Code	Feature	Conformance	Summary
3	SCH	ScheduleConfiguration	D	Supports remote configuration of a weekly schedule of setpoint transitions
4	SB	Setback	O	Supports configurable setback (or span)
5	AUTO	AutoMode	O	Supports a System Mode of Auto
6	LTNE	LocalTemperatureNotExposed	O	Thermostat does not expose the LocalTemperature Value in the LocalTemperature attribute
7	MSCH	MatterScheduleConfiguration	O	Supports enhanced schedules
8	PRES	Presets	O	Thermostat supports setpoint presets

4.3.4.1. LocalTemperatureNotExposed Feature

This feature indicates that the [Calculated Local Temperature](#) used internally is unavailable to report externally, for example due to the temperature control being done by a separate subsystem which does not offer a view into the currently measured temperature, but allows setpoints to be provided.

4.3.4.2. MatterScheduleConfiguration Feature

This feature indicates that the thermostat is capable of schedules. If this feature is supported, the thermostat SHALL support a mechanism to do time synchronization.

4.3.5. Units of Temperature

Temperatures within this cluster are represented by types using units of degree Celsius.

The temperature data type used throughout this cluster is defined in the Derived Data Types section of the Data Model.

The following temperature-related data types are also defined in and used throughout this cluster:

- [TemperatureDifference](#)