

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
3	System-Mode	System-ModeEnum	desc				O
4	CoolingSetpoint	temperature	desc				[COOL]
5	HeatingSetpoint	temperature	desc				[HEAT]

This struct provides a time of day and a set of days of the week for a state transition within a schedule. The thermostat SHALL use the following order of precedence for determining a new setpoint at the time of transition:

1. If the [PresetHandle](#) field is provided, then the setpoint for the [PresetStruct](#) in the [Presets](#) attribute with that identifier SHALL be used
2. If either the [HeatingSetpoint](#) or [CoolingSetpoint](#) is provided, then it SHALL be used
 - a. If the [SystemMode](#) field is provided, the [HeatingSetpoint](#) and [CoolingSetpoint](#) fields SHALL be interpreted using the [SystemMode](#) field
 - b. If the [SystemMode](#) field is not provided, the [HeatingSetpoint](#) and [CoolingSetpoint](#) fields SHALL be interpreted using the [SystemMode](#) field on the parent [ScheduleStruct](#)
3. If neither the [PresetHandle](#) field or any Setpoint field is provided, then the [PresetHandle](#) field on the parent [ScheduleStruct](#) SHALL be used to determine the active [PresetStruct](#)
4. If the [PresetHandle](#) is not indicated and no setpoint is provided for the current [SystemMode](#), the server SHALL use a default value for the current [SystemMode](#).

If the setpoint was derived from a preset, then the [ActivePresetHandle](#) SHALL be set to the [PresetHandle](#) of that preset.

If a [CoolingSetpoint](#) was used to determine the cooling setpoint:

- If the server supports the OCC feature, and the Occupied bit is not set on the [Occupancy](#) attribute, then the [UnoccupiedCoolingSetpoint](#) attribute SHALL be set to the [CoolingSetpoint](#)
- Otherwise, the [OccupiedCoolingSetpoint](#) attribute SHALL be set to the [CoolingSetpoint](#)

If a [HeatingSetpoint](#) was used to determine the heating setpoint:

- If the server supports the OCC feature, and the Occupied bit is not set on the [Occupancy](#) attribute, then the [UnoccupiedHeatingSetpoint](#) attribute SHALL be set to the [HeatingSetpoint](#)
- Otherwise, the [OccupiedHeatingSetpoint](#) attribute SHALL be set to the [HeatingSetpoint](#)

The [ScheduleTransitionStruct](#) SHALL be invalid if all the following are true:

- The [HeatingSetpoint](#) field is not provided