

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0x0007	PICoolingDemand	uint8	0% to 100%	P	-	R V	[COOL]
0x0008	PIHeatingDemand	uint8	0% to 100%	P	-	R V	[HEAT]
0x0009	HVACSystemTypeConfiguration	HVACSystemTypeBitmap	desc	N	0	R[W] VM	D
0x0010	LocalTemperatureCalibration	SignedTemperature	all	N	0°C	RW VM	[!LTNE]
0x0011	OccupiedCoolingSetpoint	temperature	desc	N	26°C	RW VO	COOL
0x0012	OccupiedHeatingSetpoint	temperature	desc	N	20°C	RW VO	HEAT
0x0013	UnoccupiedCoolingSetpoint	temperature	desc	N	26°C	RW VO	COOL & OCC
0x0014	UnoccupiedHeatingSetpoint	temperature	desc	N	20°C	RW VO	HEAT & OCC
0x0015	MinHeatSetpointLimit	temperature	desc	N	AbsMin-HeatSetpointLimit	RW VM	[HEAT]
0x0016	MaxHeatSetpointLimit	temperature	desc	N	AbsMax-HeatSetpointLimit	RW VM	[HEAT]
0x0017	MinCoolSetpointLimit	temperature	desc	N	AbsMin-CoolSetpointLimit	RW VM	[COOL]