

4.3.10.7.2. Effect on Receipt

Upon receipt of this command,

1. If the [PresetHandle](#) field is null, the server SHALL clear the [ActivePresetHandle](#) attribute by setting it to null.
2. Otherwise,
 - a. If this command is received with a [PresetHandle](#) such that the [Presets](#) attribute does not contain a [PresetStruct](#) whose [PresetHandle](#) field matches the value of the [PresetHandle](#), the server SHALL return a status code of INVALID_COMMAND.
 - b. The server SHALL set the [ActivePresetHandle](#) attribute to the value of the [PresetHandle](#) field.
3. The server SHALL return a status code of SUCCESS.

4.4. Fan Control Cluster

This cluster specifies an interface to control the speed of a fan.

4.4.1. Revision History

The global ClusterRevision attribute value SHALL be the highest revision number in the table below.

Revision	Description
1	Mandatory global ClusterRevision attribute added
2	New data model format and notation; Percent, speed and motion settings; General cleanup
3	Addition of AirflowDirection and Step command
4	Change conformance for FanModeSequenceEnum
5	Clarified attribute usage, added conformance column

4.4.2. Classification

Hierarchy	Role	Scope	PICS Code
Base	Application	Endpoint	FAN

4.4.3. Cluster ID

ID	Name
0x0202	Fan Control