

4.5.6.2. KeypadLockout Attribute

This attribute SHALL indicate the level of functionality that is available to the user via the keypad.

4.5.6.3. ScheduleProgrammingVisibility Attribute

This attribute is used to hide the weekly schedule programming functionality or menu on a thermostat from a user to prevent local user programming of the weekly schedule. The schedule programming MAY still be performed via a remote interface, and the thermostat MAY operate in schedule programming mode.

This attribute is designed to prevent local tampering with or disabling of schedules that MAY have been programmed by users or service providers via a more capable remote interface. The programming schedule SHALL continue to run even though it is not visible to the user locally at the thermostat.

4.6. Valve Configuration and Control Cluster

This cluster is used to configure a valve.

4.6.1. Revision History

The global ClusterRevision attribute value SHALL be the highest revision number in the table below.

Revision	Description
1	Initial revision

4.6.2. Classification

Hierarchy	Role	Scope	PICS Code
Base	Application	Endpoint	VALCC

4.6.3. Cluster ID

ID	Name
0x0081	Valve Configuration and Control

4.6.4. Features

This cluster SHALL support the FeatureMap bitmap attribute as defined below.

Bit	Code	Feature	Conformance	Summary
0	TS	TimeSync	desc	UTC time is used for time indications