

Bit	Code	Feature	Conformance	Summary
1	LVL	Level	O	Device supports setting the specific position of the valve

4.6.4.1. TimeSync Feature

This feature SHALL indicate that the valve uses Time Synchronization and UTC time to indicate duration and auto close time.

This feature SHALL NOT be supported unless the device supports the Time Synchronization cluster.

4.6.4.2. Level Feature

This feature SHALL indicate that the valve is capable of being adjusted to a specific position, as a percentage, of its full range of motion.

4.6.5. Data Types

4.6.5.1. ValveFaultBitmap Type

This data type is derived from map16.

Bit	Name	Summary	Conformance
0	GeneralFault	Unspecified fault detected	M
1	Blocked	Valve is blocked	M
2	Leaking	Valve has detected a leak	M
3	NotConnected	No valve is connected to controller	M
4	ShortCircuit	Short circuit is detected	M
5	CurrentExceeded	The available current has been exceeded	M

4.6.5.2. ValveStateEnum Type

This data type is derived from enum8.

Value	Name	Summary	Conformance
0	Closed	Valve is in closed position	M
1	Open	Valve is in open position	M