

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0x0009	ValveFault	ValveFault- Bitmap	all		0	R V	O
0x000A	LevelStep	uint8	1 to 50	F	1	R V	[LVL]

4.6.7.1. OpenDuration Attribute

This attribute SHALL indicate the total duration, in seconds, for which the valve will remain open for this current opening.

A value of null SHALL indicate the duration is not set, meaning that the valve will remain open until closed by the user or some other automation.

4.6.7.2. DefaultOpenDuration Attribute

This attribute SHALL indicate the default duration, in seconds, for which the valve will remain open, if the OpenDuration field is not present in the [Open](#) command.

A value of null SHALL indicate the duration is not set, meaning that the valve will remain open until closed by the user or some other automation.

4.6.7.3. AutoCloseTime Attribute

This attribute SHALL indicate the UTC time when the valve will close, depending on value of the [OpenDuration](#) attribute.

This attribute SHALL be null:

- When [OpenDuration](#) is null, or
- When the valve does not have a synchronized UTCTime in the Time Synchronization cluster, or
- When the valve is closed.

When the value of this attribute is earlier or equal to the current UTC time, the valve SHALL automatically transition to its closed position. The behavior of transitioning to the closed position, SHALL match the behavior described in the [Close](#) command.

If this attribute is not null and the Time Synchronization cluster receives a SetUTCTime command, modifying the current UTC time of the device, the value of this attribute SHALL be adjusted to match the new UTC time plus the value of the [RemainingDuration](#) attribute.

4.6.7.4. RemainingDuration Attribute

This attribute SHALL indicate the remaining duration, in seconds, until the valve closes.

This attribute SHALL be null:

- When [OpenDuration](#) is null, or
- When the valve is closed.