

4.2.1. Revision History

Revision	Description
1	Initial Zigbee 3.0 revision
2	New data model format and notation
3	Updated the Scenes cluster to Scenes Management with Cluster ID: 0x0062

4.2.2. Classification

Device Type ID	Device Type Name	Superset Of	Class	Scope
0x0101	Dimmable Light	On/Off Light	Simple	Endpoint

4.2.3. Conditions

See the Base Device Type definition for conformance tags.

4.2.4. Cluster Requirements

Each endpoint supporting this device type SHALL include these clusters based on the conformance defined below.

Cluster ID	Cluster Name	Client/Server	Quality	Conformance
0x0003	Identify	Server		M
0x0004	Groups	Server		M
0x0006	On/Off	Server		M
0x0008	Level Control	Server		M
0x0062	Scenes Management	Server		M
0x0406	Occupancy Sensing	Client		O

4.2.5. Element Requirements

The table below lists qualities and conformance that override the cluster specification requirements. A blank table cell means there is no change to that item and the value from the cluster specification applies.

Cluster ID	Cluster Name	Element	Name	Constraint	Access	Conformance
0x0003	Identify	Command	TriggerEffect			M
0x0006	On/Off	Feature	Lighting			M