

Device Type ID	Device Type Name	Superset Of	Class	Scope
0x0303	Pump		Simple	Endpoint

5.5.3. Conditions

See the Base Device Type definition for conformance tags.

5.5.4. Cluster Requirements

Each endpoint supporting this device type SHALL include these clusters based on the conformance defined below.

Cluster ID	Cluster Name	Client/Server	Quality	Conformance
0x0003	Identify	Server		M
0x0004	Groups	Server		O
0x0006	On/Off	Server		M
0x0008	Level Control	Server		O
0x0062	Scenes Management	Server		O
0x0200	Pump Configuration and Control	Server		M
0x0402	Temperature Measurement	Server		O
0x0402	Temperature Measurement	Client		O
0x0403	Pressure Measurement	Server		O
0x0403	Pressure Measurement	Client		O
0x0404	Flow Measurement	Server		O
0x0404	Flow Measurement	Client		O
0x0406	Occupancy Sensing	Client		O

5.5.5. Cluster Restrictions

5.5.5.1. On/Off Cluster (Server) Clarifications

The actions carried out by a Pump device on receipt of commands are shown in the following.