

Cluster ID	Cluster Name	Client/Server	Quality	Conformance
0x0003	Identify	Server		M
0x0003	Identify	Client		O
0x0004	Groups	Client		O
0x0006	On/Off	Client		M
0x0008	Level Control	Client		O
0x0062	Scenes Management	Client		O
0x0200	Pump Configuration and Control	Client		M
0x0402	Temperature Measurement	Client		O
0x0403	Pressure Measurement	Client		O
0x0404	Flow Measurement	Client		O

6.6. Generic Switch Device Type

This defines conformance for the Generic Switch device type.

6.6.1. Revision History

Revision	Description
1	Initial revision
2	Removed requirement for Fixed Label cluster (instead use TagList which was added in Descriptor cluster)
3	Updated the Scenes cluster to Scenes Management with Cluster ID: 0x0062; note that this cluster is not used in this device type (only mentioned in the informative section related to On/Off Light Switch)

6.6.2. Classification

Device Type ID	Device Type Name	Superset Of	Class	Scope
0x000F	Generic Switch		Simple	Endpoint