

issuing a visual and audible alert to indicate elevated concentration of smoke or carbon monoxide.

Smoke CO Alarms are capable of monitoring themselves and issuing visual and audible alerts for hardware faults, critical low battery conditions, and end of service. Optionally, some of the audible alerts can be temporarily silenced. Smoke CO Alarms are capable of performing a self-test which performs a diagnostic of the primary sensor and issuing a cycle of the audible and visual life safety alarm indications.

Some smoke alarms MAY be capable of adjusting sensitivity. Smoke CO Alarm MAY have the ability to detect and report humidity levels, temperature levels, and contamination levels.

7.9.1. Revision History

Revision	Description
1	Initial revision

7.9.2. Classification

Device Type ID	Device Type Name	Superset Of	Class	Scope
0x0076	Smoke CO Alarm		Simple	Endpoint

7.9.3. Conditions

See the Base Device Type definition for conformance tags.

7.9.4. Device Type Requirements

A Smoke CO Alarm device type SHALL support an instance of a Power Source device type on some endpoint. See the Power Source cluster for more information.

Device Type ID	Device Type Name	Constraint	Conformance
0x0011	Power Source	min 1	M

7.9.5. Cluster Requirements

Each endpoint supporting this device type SHALL include these clusters based on the conformance defined below.

Cluster ID	Cluster Name	Client/Server	Quality	Conformance
0x0003	Identify	Server		M
0x0004	Groups	Server		O
0x005C	Smoke CO Alarm	Server		M
0x0405	Relative Humidity Measurement	Server		O