

Cluster ID	Cluster Name	Client/Server	Quality	Conformance
0x040C	Carbon Monoxide Concentration Measurement	Server		O
0x040D	Carbon Dioxide Concentration Measurement	Server		O
0x0413	Nitrogen Dioxide Concentration Measurement	Server		O
0x0415	Ozone Concentration Measurement	Server		O
0x042A	PM2.5 Concentration Measurement	Server		O
0x042B	Formaldehyde Concentration Measurement	Server		O
0x042C	PM1 Concentration Measurement	Server		O
0x042D	PM10 Concentration Measurement	Server		O
0x042E	Total Volatile Organic Compounds Concentration Measurement	Server		O
0x042F	Radon Concentration Measurement	Server		O

7.11. Water Freeze Detector Device Type

This defines conformance to the Water Freeze Detector device type.

7.11.1. Revision History

Revision	Description
1	Initial revision

7.11.2. Classification