

Device Type ID	Device Type Name	Cluster ID	Cluster Name	Element	Name	Con-straint	Access	Confor-mance
0x0510	Electrical Sensor	0x0090	Electrical Power Measurement	Attribute	Voltage			M
0x0510	Electrical Sensor	0x0090	Electrical Power Measurement	Attribute	Active-Current			M
0x0510	Electrical Sensor	0x0091	Electrical Energy Measurement	Feature	ExportedEnergy			M
Electrical Sensor (2nd)								
0x0510	Electrical Sensor	0x001D	Descriptor	Feature	TagList			M
0x0510	Electrical Sensor	0x0090	Electrical Power Measurement	Feature	DirectCurrent			M
0x0510	Electrical Sensor	0x0090	Electrical Power Measurement	Attribute	Voltage			M
0x0510	Electrical Sensor	0x0090	Electrical Power Measurement	Attribute	Active-Current			M
0x0510	Electrical Sensor	0x0091	Electrical Energy Measurement	Feature	ExportedEnergy			M

The Power Source cluster in the Power Source device SHALL support the RECHG feature if it can be charged as well as discharged through the connection to the premises wiring.

The Electrical Sensor device SHALL also conform to the following:

- An Electrical Sensor device SHALL measure the energy and power flows of the Battery Storage device at the AC grid connection point.
- The Electrical Power Measurement cluster of this Electrical Sensor device SHALL support the PolyphasePower feature if the Battery Storage device is connected via polyphase wiring, and