

Value	Name	Summary	Conformance
0x05	Actuator	Presentation will be conveyed by actuator functionality such as through a window blind operation or in-wall relay.	M

1.2.4.2. EffectIdentifierEnum Type

This data type is derived from enum8.

Value	Name	Summary	Conformance
0x00	Blink	e.g., Light is turned on/off once.	M
0x01	Breathe	e.g., Light is turned on/off over 1 second and repeated 15 times.	M
0x02	Okay	e.g., Colored light turns green for 1 second; non-colored light flashes twice.	M
0x0B	ChannelChange	e.g., Colored light turns orange for 8 seconds; non-colored light switches to the maximum brightness for 0.5s and then minimum brightness for 7.5s.	M
0xFE	FinishEffect	Complete the current effect sequence before terminating. e.g., if in the middle of a breathe effect (as above), first complete the current 1s breathe effect and then terminate the effect.	M
0xFF	StopEffect	Terminate the effect as soon as possible.	M

1.2.4.3. EffectVariantEnum Type

This data type is derived from enum8.