

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0x0001	MinMeasuredValue	temperature	-27315 to 32766	X		R V	M
0x0002	MaxMeasuredValue	temperature	min (Min-Measured-Value + 1)	X		R V	M
0x0003	Tolerance	uint16	max 2048		0	R V	O

2.3.4.1. MeasuredValue Attribute

This attribute SHALL indicate the measured temperature.

The null value indicates that the temperature is unknown.

2.3.4.2. MinMeasuredValue Attribute

This attribute SHALL indicate the minimum value of MeasuredValue that is capable of being measured. See [Measured Value](#) for more details.

The null value indicates that the value is not available.

2.3.4.3. MaxMeasuredValue Attribute

This attribute indicates the maximum value of MeasuredValue that is capable of being measured. See [Measured Value](#) for more details.

The null value indicates that the value is not available.

2.3.4.4. Tolerance Attribute

See [Measured Value](#).

2.4. Pressure Measurement Cluster

This cluster provides an interface to pressure measurement functionality, including configuration and provision of notifications of pressure measurements.

2.4.1. Revision History

The global ClusterRevision attribute value SHALL be the highest revision number in the table below.

Revision	Description
1	Mandatory global ClusterRevision attribute added