

2.4.5.6. MinScaledValue Attribute

This attribute SHALL indicate the minimum value of ScaledValue that can be measured.

The null value indicates that the value is not available.

2.4.5.7. MaxScaledValue Attribute

This attribute SHALL indicate the maximum value of ScaledValue that can be measured.

The null value indicates that the value is not available.

2.4.5.8. ScaledTolerance Attribute

This attribute SHALL indicate the magnitude of the possible error that is associated with ScaledValue. The true value is located in the range

(ScaledValue – ScaledTolerance) to (ScaledValue + ScaledTolerance).

2.4.5.9. Scale Attribute

This attribute SHALL indicate the base 10 exponent used to obtain ScaledValue (see [ScaledValue](#)).

2.5. Flow Measurement Cluster

This cluster provides an interface to flow measurement functionality, including configuration and provision of notifications of flow measurements.

2.5.1. Revision History

The global ClusterRevision attribute value SHALL be the highest revision number in the table below.

Revision	Description
1	Mandatory global ClusterRevision attribute added
2	CCB 2241 2370
3	New data model format and notation

2.5.2. Classification

Hierarchy	Role	Scope	PICS Code
Base	Application	Endpoint	FLW

2.5.3. Cluster ID