

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0x0003	Tolerance	uint16	max 2048			R V	O

2.6.4.1. MeasuredValue Attribute

MeasuredValue represents the water content in % as follows:

$\text{MeasuredValue} = 100 \times \text{water content}$

Where $0\% \leq \text{water content} \leq 100\%$, corresponding to a MeasuredValue in the range 0 to 10000.

The maximum resolution this format allows is 0.01%.

MinMeasuredValue and MaxMeasuredValue define the range of the sensor.

The null value indicates that the measurement is unknown, otherwise the range SHALL be as described in [Measured Value](#).

MeasuredValue is updated continuously as new measurements are made.

2.6.4.2. MinMeasuredValue Attribute

The MinMeasuredValue attribute indicates the minimum value of MeasuredValue that can be measured. The null value means this attribute is not defined. See [Measured Value](#) for more details.

2.6.4.3. MaxMeasuredValue Attribute

The MaxMeasuredValue attribute indicates the maximum value of MeasuredValue that can be measured. The null value means this attribute is not defined. See [Measured Value](#) for more details.

2.6.4.4. Tolerance Attribute

See [Measured Value](#).

2.7. Occupancy Sensing Cluster

The server cluster provides an interface to occupancy sensing functionality based on one or more sensing modalities, including configuration and provision of notifications of occupancy status.

2.7.1. Revision History

The global ClusterRevision attribute value SHALL be the highest revision number in the table below.

Revision	Description
1	Mandatory global ClusterRevision attribute added
2	Physical Contact Occupancy feature with mandatory OccupancySensorTypeBitmap