

Bit	Code	Feature	Conformance	Summary
4	APPE	ApparentEnergy	P, O	Measurements report apparent energy
5	REAE	ReactiveEnergy	P, O	Measurements report reactive energy

2.12.4.1. ImportedEnergy Feature

The feature indicates the server is capable of measuring how much energy is imported by the server.

2.12.4.2. ExportedEnergy Feature

The feature indicates the server is capable of measuring how much energy is exported by the server.

2.12.4.3. CumulativeEnergy Feature

The feature indicates the server is capable of measuring how much energy has been imported or exported by the server over the device's lifetime. This measurement MAY start from when a device's firmware is updated to include this feature, when a device's firmware is updated to correct measurement errors, or when a device is factory reset.

2.12.4.4. PeriodicEnergy Feature

The feature indicates the server is capable of measuring how much energy has been imported or exported by the server during a certain period of time. The start and end times for measurement periods SHALL be determined by the server, and MAY represent overlapping periods.

2.12.5. Data Types

2.12.5.1. MeasurementTypeEnum Type

This data type is derived from enum16.

Value	Name	Summary	Conformance
0	Unspecified		M
1	Voltage	Voltage in millivolts (mV)	M
2	ActiveCurrent	Active current in milliamps (mA)	M
3	ReactiveCurrent	Reactive current in milliamps (mA)	M