

Value	Name	Summary	Conformance
8	RMSVoltage	Root mean squared voltage in millivolts (mV)	M
9	RMSCurrent	Root mean squared current in milliamps (mA)	M
10	RMSPower	Root mean squared power in milliwatts (mW)	M
11	Frequency	AC frequency in millihertz (mHz)	M
12	PowerFactor	Power Factor ratio in +/- 1/100ths of a percent.	M
13	NeutralCurrent	AC neutral current in milliamps (mA)	M
14	ElectricalEnergy	Electrical energy in milliwatt-hours (mWh)	M
15	ReactiveEnergy	Reactive power in millivolt-amp-hours reactive (mVARh)	M
16	ApparentEnergy	Apparent power in millivolt-amp-hours (mVAh)	M

2.13.5.2.1. MeasurementAccuracyRangeStruct Type

This struct represents the accuracy of a measurement for a range of measurement values. Accuracy SHALL be expressed as a maximum +/- percentage of the true value, a maximum +/- fixed value of the true value, or both.

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0	RangeMin	int64	-2^{62} to 2^{62}				M
1	RangeMax	int64	-2^{62} to 2^{62}				M
2	Percent-Max	percent100ths	all				O.a+
3	Percent-Min	percent100ths	max PercentTypical				[Percent-Max]