

MinLevel	MaxLevel	CurrentLevel	Level	%Light
1	254	100	100	1.49%
1	254	254	254	100%
170	254	1	170	10.1%
170	254	10	173	11.0%
170	254	100	203	24.8%
170	254	254	254	100%
170	230	1	170	10.1%
170	230	10	172	10.7%
170	230	100	193	19.2%
170	230	254	230	51.9%

3.1.4. Cluster List

This section lists the lighting specific clusters as specified in this chapter.

Table 7. Overview of the Lighting Clusters

Cluster ID	Cluster Name	Description
0x0300	Color Control	Attributes and commands for controlling the color of a color-capable light.

3.2. Color Control Cluster

This cluster provides an interface for changing the color of a light. Color is specified according to the [CIE 1931 Color space](#). Color control is carried out in terms of x,y values, as defined by this specification.

Additionally, color MAY optionally be controlled in terms of color temperature, or as hue and saturation values based on optionally variable RGB and W color points. It is recommended that the hue and saturation are interpreted according to the HSV (a.k.a. HSB) color model.

Control over luminance is not included, as this is provided by means of the Level Control for Lighting cluster. It is recommended that the level provided by this cluster be interpreted as representing a proportion of the maximum intensity achievable at the current color.

3.2.1. Revision History

The global ClusterRevision attribute value SHALL be the highest revision number in the table below.