

Chapter 4. HVAC

The Cluster Library is made of individual chapters such as this one. References between chapters are made using a *X.Y* notation where *X* is the chapter and *Y* is the sub-section within that chapter.

4.1. General Description

4.1.1. Introduction

The clusters specified in this document are for use typically in HVAC applications, but MAY be used in any application domain.

4.1.2. Terms

Precooling: Cooling a building in the early (cooler) part of the day, so that the thermal mass of the building decreases cooling needs in the later (hotter) part of the day.

4.1.3. Cluster List

This section lists the HVAC specific clusters as specified in this chapter.

Table 8. Overview of the HVAC Clusters

Cluster ID	Cluster Name	Description
0x0200	Pump Configuration and Control	An interface for configuring and controlling pumps.
0x0201	Thermostat	An interface for configuring and controlling the functionality of a thermostat
0x0202	Fan Control	An interface for controlling a fan
0x0204	Thermostat User Interface Configuration	An interface for configuring the user interface of a thermostat (which MAY be remote from the thermostat)
0x0081	Valve Configuration and Control	An interface for configuring and controlling the functionality of a valve

4.2. Pump Configuration and Control Cluster

The Pump Configuration and Control cluster provides an interface for the setup and control of pump devices, and the automatic reporting of pump status information. Note that control of pump speed is not included – speed is controlled by the On/Off and Level Control clusters.