

ControlMode attribute set to ConstantSpeed.

Valid range is 0 to 65,534 RPM (steps of 1 RPM).

This attribute SHALL be null if the value is invalid.

4.2.7.9. MaxConstSpeed Attribute

This attribute specifies the maximum speed the pump can achieve when it is working with the ControlMode attribute set to ConstantSpeed.

Valid range is 0 to 65,534 RPM (steps of 1 RPM).

This attribute SHALL be null if the value is invalid.

4.2.7.10. MinConstFlow Attribute

This attribute specifies the minimum flow the pump can achieve when it is working with the ControlMode attribute set to ConstantFlow.

Valid range is 0 m³/h to 6,553.4 m³/h (steps of 0.1 m³/h).

This attribute SHALL be null if the value is invalid.

4.2.7.11. MaxConstFlow Attribute

This attribute specifies the maximum flow the pump can achieve when it is working with the ControlMode attribute set to ConstantFlow.

Valid range is 0 m³/h to 6,553.4 m³/h (steps of 0.1 m³/h).

This attribute SHALL be null if the value is invalid.

4.2.7.12. MinConstTemp Attribute

This attribute specifies the minimum temperature the pump can maintain in the system when it is working with the ControlMode attribute set to ConstantTemperature.

Valid range is -273.15 °C to 327.67 °C (steps of 0.01 °C).

This attribute SHALL be null if the value is invalid.

4.2.7.13. MaxConstTemp Attribute

This attribute specifies the maximum temperature the pump can maintain in the system when it is working with the ControlMode attribute set to ConstantTemperature.

MaxConstTemp SHALL be greater than or equal to MinConstTemp

Valid range is -273.15 °C to 327.67 °C (steps of 0.01 °C).

This attribute SHALL be null if the value is invalid.

4.2.7.14. PumpStatus Attribute

This attribute specifies the activity status of the pump functions as listed in [PumpStatusBitmap](#). Where a pump controller function is active, the corresponding bit SHALL be set to 1. Where a pump