

4.3.8.17. ControlSequenceOfOperationEnum Type

This data type is derived from enum8.

Value	Name	Summary	Conformance
0	CoolingOnly	Heat and Emergency are not possible	[COOL]
1	CoolingWithReheat	Heat and Emergency are not possible	[COOL]
2	HeatingOnly	Cool and precooling (see Terms) are not possible	[HEAT]
3	HeatingWithReheat	Cool and precooling are not possible	[HEAT]
4	CoolingAndHeating	All modes are possible	[HEAT & COOL]
5	CoolingAndHeating-WithReheat	All modes are possible	[HEAT & COOL]

NOTE*CoolingAndHeating*

A thermostat indicating it supports CoolingAndHeating (or CoolingAndHeatingWithReheat) SHOULD be able to request heating or cooling on demand and will usually support the Auto SystemMode.

Systems which support cooling **or** heating, requiring external intervention to change modes or where the whole building must be in the same mode, SHOULD report CoolingOnly or HeatingOnly based on the current capability.

4.3.8.18. PresetScenarioEnum Type

This data type is derived from enum8.

Value	Name	Summary	Conformance
1	Occupied	The thermostat-controlled area is occupied	M
2	Unoccupied	The thermostat-controlled area is unoccupied	M
3	Sleep	Users are likely to be sleeping	M
4	Wake	Users are likely to be waking up	M
5	Vacation	Users are on vacation	M