

Value	Name	Summary	Conformance
7	FanOnly		O
8	Dry		O
9	Sleep		O

Table 9. Interpretation of Heat, Cool and Auto *SystemModeEnum* Values

Attribute Values	Temperature Below Heat Setpoint	Temperature Between Heat Setpoint and Cool Setpoint	Temperature Above Cool Setpoint
Heat	Temperature below target	Temperature on target	Temperature on target
Cool	Temperature on target	Temperature on target	Temperature above target
Auto	Temperature below target	Temperature on target	Temperature above target

4.3.8.22. ThermostatRunningModeEnum Type

This data type is derived from enum8.

Value	Name	Summary	Conformance
0	Off	The Thermostat does not generate demand for Cooling or Heating	O
3	Cool	Demand is only generated for Cooling	[COOL]
4	Heat	Demand is only generated for Heating	[HEAT]

4.3.8.23. TemperatureSetpointHoldEnum Type

This data type is derived from enum8.

Value	Name	Summary	Conformance
0	SetpointHoldOff	Follow scheduling program	M
1	SetpointHoldOn	Maintain current setpoint, regardless of schedule transitions	M

4.3.8.24. PresetStruct Type